

LIST OF APPROVED PRODUCTS FOR USE IN PUBLIC WATER SUPPLY IN THE UNITED KINGDOM

All approved products must be used in accordance with the specific conditions of approval, listed against the product names in Parts A-E. In addition, the following general conditions of approval apply to all approved products:

1. That use is in accordance with an Instructions for Use document. Approval holders must provide drinking water suppliers with copies of the Instructions for Use Document that was considered by the Drinking Water Inspectorate (DWI) when approval was recommended.
2. That the approval of the Authorities is obtained on condition that there shall be:
 - no change in the formulation of the approved product, including change in the source or identity of raw materials
 - no change in the manufacturing process, including location of manufacture
 - no change in designation of the approved product
 - no change in name or ownership of the organisation holding the approval
3. That the producer shall ensure that the product is tested for conformity with its formulation, and the source or identity of its raw materials, at such intervals and by such persons, as may be determined by the Authorities. The results of such testing shall be sent to the Authorities.
4. If there is suspicion that any of the above is not being followed or has been changed then notify DWI Regulation 31 team who will investigate (reg31.enquiries@defra.gov.uk)
5. That the approval is still valid

Contents

Part A	Chemicals and Filter Media	4
A.1	Flocculants and Coagulants	4
A.1.1	Products based on tannin	4
A.1.3	Products based on iron	4
A.2	Adsorbents	4
A.3	Ion Exchange Resins Systems	4
A.3.1	Ion exchange resins	4
A.3.2	Ion exchange resin based processes	6
A.5	Disinfection or Cleaning Agents of Membranes	6
A.6	Disinfectants for Emergency Use	10
A.7	Products Based on Traditional Chemicals	10
A.7.2	On-site electrolytic generation of chlorine	10
A.7.3	On-site generation of chlorine dioxide	12
A.9	Other Chemicals	13
A.10	Filter Media	16
Part B	Products for Conveyance of Water	16
B.1	Pipes	16
B.1.1	Polyethylene (PE) pipes	16
B.1.2	Polyethylene Barrier pipes	22
B.1.3	Polyvinylchloride (PVC) pipes	23
B.1.4	Acrylonitrile-butadiene-styrene copolymer (ABS)	24
B.1.5	Polyethylene terephthalate (PET)	24
B.1.6	Glass reinforced plastic (GRP) pipes	24
B.1.7	Cement mortar lined pipes	24
B.1.7.1	Cement mortar lined pipes without seal coat	24
B.1.7.2	Cement mortar lined pipes with seal coat	26
B.1.9	Pipes coated with factory applied epoxy resin	26
B.1.10	Stainless steel pipes	29
B.1.11	Coated pipes suitable for total immersion in water	34
B.2	Well Casings, Screens and Rising Mains	34
B.3	Products for Conveyance of Water -Emergency Use	37
B.3.1	Hoses	37
B.3.2	Bowsers/tanks	38
B.3.3	Liner bags	39
Part C	Lining, Coatings, Sealant and Repair Materials	39
C.1	In-situ Installed (tubular) pipe linings	39
C.2	In-situ applied Pipe Coatings	40
C.2.2	Coatings based on polyurethane	40
C.2.3	Coatings for small diameter pipes	41
C.3	Site applied coatings for water retaining structures	41
C.3.1	Coatings based on epoxy resins	41
C.3.2	Coatings based on polyurethane	42

C.4	Flexible covers and linings for water retaining structures	43
C.5	Cementitious coatings.....	44
C.6	Sealant & Repair Materials	47
Part D	Membrane and Filtration Systems.....	53
D.1	Membrane and Filtration Elements/Systems	53
D.2	Vessels and Containers for Membrane and Filtration Elements.....	58
D.4	Filter Media Containing Systems	59
Part E	Other Water Treatment Works Installations	60
E.1	Tanks.....	60
E.2	Underdrains.....	65
E.3	Pressure vessels.....	66
E.4	Other Products used for the treatment of water.....	68
Index by Product Name		74

PART A CHEMICALS AND FILTER MEDIA

It is the responsibility of the drinking water suppliers to ensure that

(a) the method and manner of use; and

(b) the purity of these chemicals and products are such that the water treated meets the requirements of the relevant regulations. Where appropriate, additional specific conditions of approval are listed against the chemical or product.

Approval holders and water companies should be aware that products or substances that claim to have a biocidal effect or are used as biocides may require authorisation under the Biocidal Products Regulation. HSE is the UK competent authority for the Biocidal Products Regulation and so any queries about whether that legislation applies to a specific product or substance should be addressed to biocidesenquiries@hse.gov.uk

A.1 Flocculants and Coagulants

A.1.1 Products based on tannin

This section contains no products

A.1.3 Products based on iron

Northern Ireland Water

Sirofloc Magnetite TM M-10

56/4/1338

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sirofloc Magnetite TM T10 Instructions for use V001 Issue no. V001 Issue Date: 03/12/2018

Approval expiry date: 31 October 2029

A.2 Adsorbents

This section contains no products

A.3 Ion Exchange Resins Systems

A.3.1 Ion exchange resins

Barr + Wray Ltd

Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 141204

56/4/1238

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BW Colour/Organics Removal Ion Exchange Resins (Ref code:BW141204) – IFU Issue no. Issue 3 Issue Date: 31/10/2024

Approval expiry date: 10 January 2027

Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 200613

56/4/1239

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BW Colour/Organics Removal Ion Exchange Resins (Ref code:BW200613) – IFU Issue no. Issue 3 Issue Date: 31/10/2024

Approval expiry date: 10 January 2027

Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 341817

56/4/1237

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Colour/Organics Removal Ion Exchange Resin Issue no. 2 Issue Date: 01/11/2021

Approval expiry date: 10 January 2027

Ixom Operations Pty Ltd

MIEX DOC Resin

56/4/550

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MIEX DOC Resin. Instructions For Use. Version V5. Date of Issue: 26/08/2015

Approval expiry date: 1 September 2026

MIEX Gold

56/4/1140

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Revision 5, Date of Issue 03 September 2020

Approval expiry date: 18 October 2025

Jacobi Carbons

Resinex KW-H

56/4/1151

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Resinex KW-H - 1-1016-14 Issue no. 2 Issue Date: 28/03/2022

Approval expiry date: 21 July 2027

Lanxess Deutschland GmbH

Lewatit S 5128

56/4/1193

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) Lewatit S 5128 Issue no. Version 02 Issue Date: 22/09/2021

Approval expiry date: 5 March 2027

Purolite International Ltd

Purolite A520E nitrate selective anion exchange resin

56/4/11

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: A520E nitrate removal from municipal potable water supplies Issue no. 4 Issue Date: 01/11/2021

Approval expiry date: 27 June 2027

A.3.2 Ion exchange resin based processes

Barr + Wray Ltd

Ion exchange colour removal system

56/4/1176

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr and Wray Colour Removal System Issue 2 - Sept 2021

Approval expiry date: 5 December 2026

A.5 Disinfection or Cleaning Agents of Membranes

During the approval process there is no evaluation of a product's effectiveness, only of its safety in use. An approval given in this section does not certify that the Authorities are satisfied that the product is effective, but only that it is safe for use in accordance with the Instructions for Use supplied.

The fact that a product is approved does not justify any claim about its effectiveness.

Brenntag UK & Ireland

Citric Acid 50% Solution

56/4/1333

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Citric Acid 50% Solution:- Instructions for Use Issue no. Version 3 Issue Date: 30/10/2023

Approval expiry date: 16 February 2029

Genesys International Ltd

Genesol 61

56/4/1205

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: DWI-61-IFU /2, Issue: 2, Date of Issue: 15th Sept 2020

Approval expiry date: 18 November 2025

Genesol 704

56/4/1319

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesol 704 Issue no. DWI-704-IFU/1 Issue Date: 30/04/2018

Approval expiry date: 18 September 2028

Genesys CAS

56/4/1253

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys CAS Issue no. 2 Issue Date: 16/02/2022

Approval expiry date: 16 May 2027

Genesys LF

56/4/495

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys LF DWI-IFU-/6 Issue no. 6 Issue Date: 08/09/2023

Approval expiry date: 22 October 2028

Genesys LF60

56/4/783

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys LF60 Issue no. DWI-LF60 – IFU / 5 Issue Date: 26/09/2024

Approval expiry date: 9 October 2029

Genesys LS

56/4/781

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys LS Issue no. DWI-LS-IFU-5 Issue Date: 27/09/2024

Approval expiry date: 9 October 2029

Genesys SI

56/4/593

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys SI Issue no. DWI-SI-IFU-4 Issue Date: 29/04/2019

Approval expiry date: 5 November 2029

Genesys SW

56/4/524

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Genesys SW - DWI – SW – IFU Issue no. 6 Issue Date: 06/10/2023

Approval expiry date: 22 October 2028

Kobell Fluid Technology Ltd

Guardsman GT190 Antiscalant for Membrane Systems

56/4/1123

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Guardsman Anti-scalant Guidance Issue no. Y240123 Issue Date: 11/12/2023

Maximum dosing not to exceed 10 mg/L.

Approval expiry date: 10 March 2029

Kurita UK Ltd

RoCide DB20

56/4/964

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoCide DB20 Instructions for Use, Issue 5 Date: 04/12/2020

Approval expiry date: 14 January 2026

RoClean L211

56/4/945

Conditions of Approval:

Approval expiry date: 15 October 2025

RoClean L403

56/4/855

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean L403 Instruction for Use Issue no. 7 Issue Date: 03/01/2022

Approval expiry date: 30 May 2027

RoClean P111

56/4/737

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean P111 Instructions for Use Issue no. 4 Issue Date: 01/12/2022

Approval expiry date: 5 July 2028

RoClean P303

56/4/1544

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean P303 Instructions for Use Issue no. 003 Issue Date: 06/02/2024

Approval expiry date: 31 October 2029

Vitec 3000

56/4/457

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 3000 Issue no. 6 Issue Date: 01/12/2022

Approval expiry date: 17 August 2028

Vitec 4000

56/4/1529

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Vitec 4000 v4.docx Issue no. 4 Issue Date: 12/06/2023

Approval expiry date: 21 January 2029

Vitec 7000

56/4/801

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 7000 Issue no. 6 Issue Date: 07/12/2020

Approval expiry date: 8 April 2030

Vitec 7000a

56/4/869

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 7000a, Issue: 6, Date 07/12/2020

Approval expiry date: 14 July 2025

SUEZ Water Technologies & Solutions

Kleen* MCT524

56/4/1007

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen MCT524 Issue no. 2 Issue Date: 01/05/2018

Approval expiry date: 28 September 2027

Veolia Water Technologies & Solutions

Hypersperse MDC711

56/4/1508

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse MDC711 IFU- Instructions for use Issue no. 2 Issue Date: 14/06/2023

Approval expiry date: 26 February 2029

Kleen MCT405

56/4/1509

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen MCT405 - IFU Instruction for use Issue no. 3 Issue Date: 14/06/2023

Approval expiry date: 26 February 2029

Veolia Water Technologies & Solutions (Belgium)

Hypersperse MDC704i

56/4/1499

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse MDC704i Issue no. 3 Issue Date: 01/10/2024

Approval expiry date: 15 December 2029

Kleen MCT105

56/4/1506

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Kleen MCT105 - Veolia Jun2023 Issue no. 1 Issue Date: 14/06/2023

Approval expiry date: 25 March 2029

Water Treatment Products Limited

WTP RO 411

56/4/821

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Water Treatment Products Ltd WTP RO411 reverse osmosis antiscalant Issue no. RO411 - IFU Issue 3/A Issue Date: 15/01/2020

Approval expiry date: 4 July 2030

WTP RO 413

56/4/822

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Water Treatment Products Ltd WTP RO413 reverse osmosis antiscalant Issue no. 3/A Issue Date: 15/01/2020

Approval expiry date: 5 July 2030

A.6 Disinfectants for Emergency Use

Disinfectants for emergency use are no longer approved and listed under the requirements of relevant regulations. Guidance upon the choice and use of disinfectants in an emergency is provided in Advice Sheet 9 (<http://www.dwi.gov.uk/drinking-water-products/advice-and-approval/Advicesheet9.pdf>).

Approvals of previously listed disinfectants for emergency use have been revoked – see Information Letter 08/2008 (http://www.dwi.gov.uk/stakeholders/information-letters/2008/08_2008.pdf)

This section contains no products

A.7 Products Based on Traditional Chemicals

A.7.2 On-site electrolytic generation of chlorine

Products in this section are not fully covered by EN 901 (sodium hypochlorite) and must conform to the following conditions of use:

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and
- (ii) the treated water must not contain more than 700 µg/l chlorate.

Bridge Biotechnology Ltd

Aquaclear ESOL Disinfection System

56/4/1406

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aquaclear ESOL Disinfection System: Instructions for Use (IFU) Issue no. Issue: 01 Issue Date: 09/11/2020

Approval expiry date: 22 November 2025

Evoqua Water Technologies GmbH (Germany)

Wallace & Tieman OSEC® B-PLUS

56/4/1450

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OSEC® B-PLUS Instruction Manual Issue no. WT.085.105.000.IE.IM.0921 Issue Date: 05/09/2021

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant regulations, and
- (ii) the treated water must not contain more than 700µg/l chlorate.

Approval expiry date: 13 January 2027

Wallace & Tiernan OSEC® L

56/4/775

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OSEC® L Instruction Manual - Issue no. WT.085.055.000.DE.IM.1121 Issue Date: 22/12/2021

(i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant regulations, and

(ii) the treated water must not contain more than 700ug/l chlorate.

Approval expiry date: 13 January 2027

Evoqua Water Technologies Ltd

Wallace & Tiernan OSEC® B-PAK

56/4/1451

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OSEC® B-PAK Instruction Manual - Issue no. WT.085.090.000.DE.IM.0921 Issue Date:

i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant regulations, and

(ii) the treated water must not contain more than 700ug/l chlorate.

Approval expiry date: 13 January 2027

Grundfos Holding A/S

SELCOPERM System SES 125-2000

56/4/864

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SELCOPERM System SES 125-2000 Issue no. 004 Issue Date: 02/05/2023

(i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and

(ii) the treated water must not contain more than 700 µg/l chlorate.

Approval expiry date: 2 May 2028

A.7.3 On-site generation of chlorine dioxide

Products in this section are not fully covered by EN 12671 (chlorine dioxide). The following products must conform to the following conditions of use:

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and
- (ii) the combined concentration of chlorine dioxide, chlorite and chlorate shall not exceed 0.5 mg/l as chlorine dioxide in the water entering supply.

International Water Solutions Ltd

Chlorine Dioxide generated by Xziox

56/4/998

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for the Preparation and Use of Xziox Chlorine Dioxide for Issue no. 1.8 Issue Date: 27/01/2016

- (i) the method of use and the purity of the output of this product shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations, and
- (ii) the combined concentration of chlorine dioxide, chlorite and chlorate shall not exceed 0.5mg/l as chlorine dioxide in the water entering supply.

Approval expiry date: 30 January 2026

Oxiflo Ltd

Oxiflo 1 & 2 Chlorine Dioxide

56/4/1415

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OXIFLO Instructions for the Preparation and Use of Oxiflo Chlorine Dioxide for Final Disinfection (IFU) Issue no. V5 Issue Date: 22/03/2021

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and
- (ii) the combined concentration of chlorine dioxide, chlorite and chlorate shall not exceed 0.5 mg/l as chlorine dioxide in the water entering supply.

Approval expiry date: 20 January 2027

A.9 Other Chemicals

Airedale Chemical Company Ltd

AiropHos 750PWG

56/4/960

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: AIROPHOS 750 PWG - Instructions for Use Issue no. 4 Issue Date: 18/02/2025

Approval expiry date: 24 March 2030

Aqua Smart Inc.

SEAQUEST

56/4/202

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Seaquest Instructions for Use Issue no. V2 Issue Date: 06/03/2022

Approval expiry date: 23 October 2025

BioBullets Ltd

Silver Bullets 2000

56/4/1000

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Silver Bullets 2000 Issue no. 3 Issue Date: 15/05/2023
This product can only be used in raw water treatment

Approval expiry date: 18 September 2028

Brenntag UK & Ireland

Clorious2 Care

56/4/1196

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Clorious2 care Instructions for Use, Issue 5, Date 23/02/2021
The product should not exceed the approved shelf life of 3 months or storage temperatures as detailed in the IFU

Approval expiry date: 10 March 2026

TP Chlor

56/4/979

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 dated 19/6/15

The method of use and purity of this product shall be such that in the case of water for public supply the water so treated meets the requirements of the relevant regulations.

Approval expiry date: 21 October 2025

TP Chlor plus

56/4/1190

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 dated 19/6/15

The method of use and purity of this product shall be such that in the case of water for public supply the water so treated meets the requirements of the relevant regulations.

Approval expiry date: 21 October 2025

Buxton Lime Limited

Kalic HSD

56/4/1206

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kalic HSD for pH Control and Water Softening in Drinking Water Processes Issue no. 3 Issue Date: 13/11/2024

Approval expiry date: 18 May 2030

Clinty Chemicals Limited

Purafloc TM 001

56/4/1378

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use: Purafloc 001 Issue no. 3 Issue Date: 21/05/2024

Approval expiry date: 6 November 2029

Clogrennane Lime Ltd

Hydraflow

56/4/1424

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hydrapure IFU Issue no. 2 Issue Date: 16/04/2021

Approval expiry date: 6 September 2026

EFT Holdings AG

Abulox

56/4/1491

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Abulox (R) Instructions for Use Issue no. EFT/AB/IFU/001 Issue Date: 13/07/2023

Approval expiry date: 27 July 2028

Industrial Chemicals Ltd

Thycal

56/4/1025

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use :THYCAL Issue no. 3 Issue Date: 10/06/2021

Approval expiry date: 1 September 2026

JFI Limited

Purafloc TM 001

56/4/1355

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use: Purafloc(TM) 001 Issue no. 3 Issue Date: 21/05/2024

Approval expiry date: 18 July 2029

Omya

Omyalime – MJ 30%

56/4/1540

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE Omyalime 30 – MJ 30% Issue no. 1.0 Issue Date: 05/09/2023

Approval expiry date: 2 October 2029

SUEZ Advanced Solutions UK Ltd

iDroloc

56/4/1422

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: iDroloc (Helium Gas Injection Device)
(SAS_INST_IDROLOC), Issue 5, Issue Date: 15/02/2021

Approval expiry date: 7 April 2026

Veolia Water Technologies & Solutions

BetzDearborn DCL32

56/4/1505

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BetzDearborn DCL32 Issue no. 1 Issue Date: 19/06/2023
This product shall not be dosed in excess of 4.99 parts per million (mg/L).

Approval expiry date: 28 January 2029

Veolia Water Technologies & Solutions (Belgium)

Hypersperse MSI310

56/4/1510

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Hypersperse MSI310 - Veolia Jun2023 Issue no. 3 Issue Date: 14/06/2023

Approval expiry date: 12 February 2030

Kleen MCT407

56/4/1507

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen MCT407 Issue no. 1 Issue Date: 14/06/2023

Approval expiry date: 9 October 2028

WCS Services Ltd (trading as B&V Chemicals)

Ultralox 40

56/4/1530

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Ultralox 40 Official Instructions for Use Issue no. 6 Issue Date: 01/01/2024

The product should not exceed the approved shelf life of 6 months or storage temperatures as detailed in the IFU

Approval expiry date: 9 January 2029

A.10 Filter Media

Dryden Aqua Ltd

AFM Activated Filter Media

56/4/382

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: AFM activated filter media Issue no. V25.0(Metric) Issue Date: 01/05/2025

Not applicable with Slow Bed Sand Filters

Approval expiry date: 28 May 2030

PART B PRODUCTS FOR CONVEYANCE OF WATER

B.1 Pipes

Pipelife Norge AS

PIPELIFE BLACK PE100-RC PIPE

56/4/1488

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pipelife Black PE100-RC Pipe Instructions For Use Issue no. 1 Issue Date: 28/04/2023

Approval expiry date: 26 February 2029

B.1.1 Polyethylene (PE) pipes

Centraltubi SPA

Centraltubi

56/4/913

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Manual of use for Centraltubi PE Pipe 3rd Revision Jan 2019

Approval expiry date: 1 December 2025

Safe 10

56/4/1366

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SAFE 10 - Manual of Use Issue no. 3rd Revision Issue Date: 01/07/2024

Approval expiry date: 7 November 2029

Cork Plastics

CP Polytec 100

56/4/1351

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE OF CP POLYTEC PE100 EXTERNAL BLUE & INTERNAL BLACK POLYETHYLENE PIPE FOR SUPPLY OF DRINKING WATER UNDER PRESSURE Issue no. Issue 2 Issue Date: 13/12/2024

N/A

Approval expiry date: 17 March 2030

Egeplast International GmbH

egeclean (+)

56/4/1157

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use egeclean plus pipes Issue no. Rev.-Nr.: 3 Issue Date: 15/12/2021

Approval expiry date: 4 March 2029

egeclean 9010

56/4/1158

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: egeclean PE100/egeclean 9010 Issue no. IFU - UK Rev.-Nr.: 3 Issue Date: 15/12/2021

Approval expiry date: 9 August 2028

egeclean PE100

56/4/1156

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: egeclean P100/egeclean 9010 Issue no. 3 Issue Date: 15/12/2021

Approval expiry date: 7 November 2029

egelen PE 100 Blue & egelen PE100 Black

56/4/436

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE-HD PE100 in Black and Blue Issue no. 13 Issue Date: 25/01/2024

Approval expiry date: 6 November 2029

Egeplast 9010

56/4/1065

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use PE-HD PE100 in Black and Blue Issue no. 13 Issue Date: 25/01/2024

Approval expiry date: 9 August 2028

egeplast egelen (+) Plus Pipe

56/4/1111

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Peelable layer pipes Issue no. IFU - UK Rev.-Nr.: 13 Issue Date: 25/01/2024

Approval expiry date: 28 January 2029

George Fischer Sales Ltd

GF PE100 Black Pipe

56/4/957

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: GF PE100 Pressure Pipe (black) Issue no. 3 Issue Date: 08/10/2009

Approval expiry date: 30 March 2030

Gerodur MPM Kunststoffverarbeitung GmbH & Co. KG

GEROthen® COEX

56/4/1370

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Gerodur, GEROthen® Pipes – products and design No 01 Issue no. Issue No: 01 Issue Date: 13/08/2019

Approval expiry date: 8 May 2030

GPS

GPS B Light Blue Polyethylene Pipe

56/4/242

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU GPS B Blue PE80 Polyethylen Pipe Issue no. 04 Issue Date: 08/09/2021

Approval expiry date: 10 June 2027

GPS Black

56/4/851

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU GPS PE100 Black 2021.pdf

Approval expiry date: 6 November 2026

GPS Black 3C

56/4/871

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - GPS 3c 2021 Issue no. Issue Date: 01/01/2021

Approval expiry date: 6 November 2026

GPS Blue

56/4/1026

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use GPS PE100 Blue 2021 Issue no. 1 Issue Date: 01/01/2021

Approval expiry date: 6 November 2026

GPS Blue 3C

56/4/853

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - GPS 3c 2021 Issue no. Issue Date: 01/01/2021

Approval expiry date: 6 November 2026

GPS Excel NB Type V

56/4/1050

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: EXCEL NB TYPE V Issue no. 4 Issue Date: 22/07/2022

Approval expiry date: 16 October 2027

GPS N Black Polyethylene Pipe

56/4/1260

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: GPS N Black Polyethylene Pipe Issue no. 2 Issue Date: 08/09/2021

Approval expiry date: 22 May 2027

GPS N Blue PE80 Pipe

56/4/651

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aliaxis UK IFU GPS Blue N PE80 Issue 4 - 2024 Issue no. 4 Issue Date: 16/07/2024

Approval expiry date: 31 October 2029

GPS Protecta-Line 3c

56/4/873

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE pipes and coils made from PE80 and PE100 Materials IFU Issue No.9 Issue no. 9 Issue Date: 25/07/2024

Approval expiry date: 31 October 2029

Idrotherm 2000 spa

RENO 100

56/4/1168

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RENO 100 PE100 Pressure pipes (black with blue stripes)
Issue no. 3 Issue Date: 20/05/2025

Approval expiry date: 28 May 2030

Reno 100 Plus

56/4/1384

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Idrotherm 2000 Instructions for Use (IFU) – Reno 100+ PE100 pressure pipes (black inner layer/ blue outer layer) Issue:1 Ref: 19MM-DWI Dated: 12/11/19

Approval expiry date: 9 December 2025

Peak Pipe Systems

Peak Pipe Systems

56/4/548

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SIMONA PEAK PIPE SYSTEMS LIMITED, 'SIMONA PEAK PIPE SYSTEMS' POLYETHYLENE PIPE Issue no. 10 Issue Date: 17/12/2024

Approval expiry date: 30 April 2030

Pipelife Ireland Limited

Qual-plast HDPE Pipe

56/4/997

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Qual-PLAST MDPE & HDPE Pipe Systems Instructions ; Issue:03 ; Issue Date: 05/05/2021

Approval expiry date: 21 August 2026

Qual-plast MDPE Pipe

56/4/240

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Qual-PLAST Piping MDPE & HDPE pipe systems - Instructions for Use (IFU) Issue no. 4 Issue Date: 05/01/2022

Approval expiry date: 23 July 2027

QualPLAST Polyethylene MDPE co-extruded pipe

56/4/1282

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Qual-PLAST Piping MDPE & HDPE pipe systems - Instructions for Use (IFU) Issue no. 4 Issue Date: 05/01/2022

Approval expiry date: 23 August 2027

Polypipe Ltd (Trading as Polypipe Building Products)

Black PE80 Polyethylene Pipes

56/4/968

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Polypipe Building Products' PE 80 Black Polyethylene Pressure Pipes To BS EN 12201-2 Made From Ineos Eltex Tub 171 Black Polyethylene Compound Issue no. 4 Issue Date: 12/05/2025
Suitable for use above ground only.

Approval expiry date: 12 May 2030

Black PE80 Polyethylene Pipes (ME3440)

56/4/986

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue 1, 7 July 2016

Approval expiry date: 8 April 2026

Blue PE80 Polyethylene Pipes

56/4/970

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR POLYPIPE BUILDING PRODUCTS' PE 80 BLUE POLYETHYLENE PRESSURE PIPES TO BS EN 12201-2 MADE FROM BOREALIS BORSAFE ME3444 BLUE POLYETHYLENE COMPOUND Issue no. Document PSNR001, Issue number 4 Issue Date: 18/02/2025

Approval expiry date: 9 June 2030

Blue PE80 Polyethylene Pipes (PC002 50R698)

56/4/1120

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR POLYPIPE BUILDING PRODUCTS' PE 80 BLUE POLYETHYLENE PRESSURE PIPES TO BS EN 12201-2 MADE FROM INEOS ELTEX PC 002-50 R968 BLUE POLYETHYLENE COMPOUND Issue no. PS 161 Issue 1 Issue Date: 26/09/2013

Approval expiry date: 20 May 2029

Polypipe Black PE100 Polyethylene Pipes (TUB121N3000)

56/4/1343

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: POLYPIPE BUILDING PRODUCTS' PE 100 BLACK POLYETHYLENE PRESSURE PIPES TO BS EN 12201-2 MADE FROM ELTEX TUB121N 3000 POLYETHYLENE COMPOUND Issue no. PSNR0006; Issue 2 Issue Date: 05/12/2023

Pipes for above ground use only

Approval expiry date: 7 December 2028

Polypipe Blue PE100 Polyethylene Pipes (TUB124N 2025)

56/4/1514

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE 100 BLUE POLYETHYLENE PRESSURE PIPES TO BS EN 12201-2 MADE FROM ELTEX TUB124N 2025 POLYETHYLENE COMPOUND - PSNR005 Issue no. 02 Issue Date: 10/10/2023

Approval expiry date: 23 January 2029

Public Sewer Services Limited

Wavin Compact Pipe

56/4/1417

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wavin Compact Pipe Issue no. 4 Issue Date: 01/03/2023
Curing after the reforming process must be undertaken for 24 hrs at a temperature no less than 7° C and return to service after an additional 48 hrs after setting required fix points.

Approval expiry date: 19 December 2028

Radius Subterra – a part of RadiusPlus Ltd

Subcoil

56/4/461

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 6.

Approval expiry date: 1 October 2025

Radius Systems Ltd

High Performance SC100 Dark Blue Pipe PE100 pipe including Clean Pipe

56/4/939

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Polyethylene Pipe - Instruction for Use High Performance SC 100 Dark Blue PE100 pipe including Clean Pipe Issue no. 04 Issue Date: 21/01/2016

Approval expiry date: 16 November 2027

PE100 High Performance Profuse Pipe Including Factory Sealed 56/4/1243

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: High Performance SC 100 Dark Blue PE100 pipe including Clean Pipe Issue no. 4 Issue Date: 21/01/2016

Approval expiry date: 30 June 2027

PE100 High Performance Profuse Pipe Including Factory Sealed 56/4/943

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE100 High Performance Profuse Pipe including Clean Pipe Issue no. 03 Issue Date: 21/01/2016

Approval expiry date: 16 November 2027

SC100 (PE100) XL large diameter / heavy wall dark blue potable water pipe

56/4/1146

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 01, dated 02/09/2015

Approval expiry date: 8 September 2025

SDS Pipe Systems Ltd

Weholite Pipe and Panels

56/4/513

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Weholite HDPE Tanks (Pipes and Panels) & Weholite HDPE Pipes Issue no. 6 Issue Date: 06/10/2022

Approval expiry date: 10 November 2027

B.1.2 Polyethylene Barrier pipes

Egeplast International GmbH

egeplast SLA Barrier Pipes

56/4/1109

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use egeplast SLA Barrier Pipe Issue no. 14
Issue Date: 08/05/2025

Approval expiry date: 5 May 2030

GPS

GPS Protecta-Line

56/4/872

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aliaxis UK IFU Protecta-line Issue No.9 July 2024 Issue no. 9
Issue Date: 25/07/2024

Approval expiry date: 31 October 2029

Polypipe Ltd (Trading as Polypipe Building Products)

Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes

56/4/857

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use Document For Polypipe Building Products' Polyguard PE/Al/PE Pressure Pipe to WIS 4-32-19 Made From Ineos Eltex PC-002-50 R568 Blue Polyethylene/Novelis Aluminium. Document Reference: PSNR003. Issue No. 2. Dated 29/05/2020

Approval expiry date: 20 September 2025

Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes (ME3444)

56/4/1516

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR POLYPIPE BUILDING PRODUCTS' POLYGUARD PE/Al/PE PRESSURE PIPES KITEMARKED TO BS8588 AND MADE FROM BOREALIS BORSAFE ME 3444 BLUE POLYETHYLENE/NOVELIS ALUMINIUM Issue no. PS 160, Issue 2 Issue Date: 10/04/2024

Approval expiry date: 31 October 2029

B.1.3 Polyvinylchloride (PVC) pipes

Please note that all approved PVC pipes are made with non-lead stabilisers.

Durapipe Ltd

Durapipe Premium PVC-U-PVC

56/4/1226

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PVC-u Premium Technical Specifications Issue no. 3 Issue Date: 19/11/2018
Approval expiry date: 23 March 2027

Dyka B.V.

Dyka Grey PVC-U Pipe NGS

56/4/637

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PVC-u Technical Specification Issue no. 2 Issue Date: 20/09/2021
Approval expiry date: 2 November 2026

George Fischer Sales Ltd

GF DEKADUR PVC-U pressure pipe

56/4/1231

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE (IFU) - DEKADUR PVC-U PRESSURE PIPE Issue no. 3 Issue Date: 17/06/2022
Approval expiry date: 16 January 2028

GF PVC-U Inch Pipe

56/4/1235

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE (IFU) - GF PVC-U Inch Pipe Issue no. 1 Issue Date: 27/07/2016
Approval expiry date: 3 April 2028

Molecor Tecnología SL

TOM PVC-O

56/4/1568

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: TOM pipes and ecoFITTOM fittings in Oriented PVC (PVC-O) Issue no. 5 Issue Date: 27/01/2025
Approval expiry date: 19 March 2030

B.1.4 Acrylonitrile-butadiene-styrene copolymer (ABS)

Durapipe Ltd

Durapipe ABS

56/4/660

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aliaxis UK – Aliaxis UK ABS Pipes & Fittings Made from Type S Issue no. 09 Issue Date: 15/06/2021

Approval expiry date: 27 January 2027

B.1.5 Polyethylene terephthalate (PET)

This section contains no products

B.1.6 Glass reinforced plastic (GRP) pipes

Amiblu Technology AS

Flowtite Pipe Uniaxial

56/4/1264

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTION FOR USE OF FLOWTITE DRINKING WATER PRODUCTS APPROVED IN UNITED KINGDOM Issue no. 1.0 Issue Date: 01/08/2019

Approval expiry date: 14 April 2028

B.1.7 Cement mortar lined pipes

For Products in this section, the following conditions applies:

Before connection to the supply, the water undertaker or their appointed agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations.

B.1.7.1 Cement mortar lined pipes without seal coat

Axson BS Coatings

Eurokote® 468 THIXO 500 Brun Rouge

56/4/1405

Conditions of Approval:

Approval expiry date: 16 October 2025

Electrosteel Castings Ltd

Electrofresh Ductile Iron Pipe

56/4/992

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use for Electrofresh Pipes at SiteWork
Instruction: WC-04-02 Issue No: 04 Rev. A Issue Date: 20.11.2019
Before connection to supply, the water undertaker or their approved agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant regulations.

Approval expiry date: 2 August 2026

Erciyas Celik Boru Sanayi A.S

Erciyas Steel Water Pipe – Cement Lined

56/4/1047

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: TA-04-13 Issue no. 2 Issue Date: 01/02/2021

Approval expiry date: 11 December 2026

European Pipeline Group

European Pipeline Group Svobodny Sokol Ductile Iron Pipe

56/4/1114

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use of Ductile Iron Pipes produced by OOO "Lipetsk Pipe Company Svobodny Sokol" Issue no. Edition No 1
Issue Date: 18/03/2016

Approval expiry date: 23 January 2029

Jindal Saw Ltd

JSAW-JAL-11A

56/4/935

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INFORMATION FOR USE DOCUMENT PRODUCT NAME "JSAW-JAL-11A" Issue no. 04 Issue Date: 08/12/2022

Approval expiry date: 11 January 2028

JSAW-JAL-1A

56/4/933

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INFORMATION FOR USE DOCUMENT PRODUCT NAME: "JSAW-JAL-1A" Issue no. JSAW-IFU-DI-DWI-OPC-001 Rev.03
Issue Date: 20/07/2023

Approval expiry date: 30 July 2028

Saint-Gobain PAM UK Ltd

System CL

56/4/283

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: System CL pipes Issue no. 10 Issue Date: 05/07/2023
1) This product is not suitable for total immersion in water.

Approval expiry date: 12 July 2028

Superior Pipeline Products Ltd

System Cement Mortar Lined Ductile Iron Pipe

56/4/990

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SUPERIOR PIPELINE PRODUCTS. INSTRUCTIONS FOR USE. SYSTEM CEMENT MORTAR LINED DUCTILE IRON PIPE
Issue no. 4 Issue Date: 31/03/2017

Approval expiry date: 23 October 2027

B.1.7.2 Cement mortar lined pipes with seal coat

Electrosteel Castings Ltd

Electrofresh Plus Pipes

56/4/537

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Electrofresh plus pipes at site Issue no. 04 Issue Date: 01/04/2017

Approval expiry date: 2 August 2026

Saint-Gobain PAM UK Ltd

System XL

56/4/1317

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: System XL. Issue no. 10 Issue Date: 29/09/2023
1) This product must be manufactured in accordance with the DWI accepted seal coating instruction for use document.
2) This product is not suitable for immersion in drinking water.

Approval expiry date: 12 July 2028

B.1.9 Pipes coated with factory applied epoxy resin

Borusan Mannesmann Boru San. Ve Tic. A.S.

**Internally Coated Spiral Welded (HSAW) Steel Line Pipes with Eurokote
468 THIXO 500 Brun rouge**

56/4/1391

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use of EUROKOTE 468 Thixo 500 Lining of SAWH - Spiral Welded Line Pipes Issue no. GSB-KLT-IFU-ETX-001 Rev.3 Issue Date: 11/03/2022

Approval expiry date: 10 March 2027

Erciyas Celik Boru Sanayi A.S

Steel Water Pipes line with epoxy coating Eurokote 468 Thixo

56/4/1001

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTION FOR USE - ERCIYAS Pipeline Systems Steel Water Pipes lined with epoxy coating EUROKOTE 468 Thixo Issue no. TA-04-30 Rev 3 Issue Date: 12/06/2023

Approval expiry date: 1 August 2029

Freeflow Pipesystems Ltd

Fabricated Pipework and Fittings coated with Resicoat R4-FB HKC71R

56/4/817

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Fabricated Pipework and Fittings Coated with Resicoat R4-FB HKC71R Issue no. 11 Issue Date: 10/11/2022

Approval expiry date: 27 April 2030

Leyfos Plastics Limited

Resicoat R4-FB Coated Steel Pipes and Fittings

56/4/1460

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Documents (IFU): Resicoat R4 Green Coated Pipes and Fittings Issue no. LEYDW102 Issue Number 01 Issue Date: 01/06/2021

Approval expiry date: 20 June 2027

Lortub S.A.S.

LORTUB Steel Water Fittings lined with High Performance Eurokote 468

Thixo

56/4/1204

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: LORTUB FITTINGS EPOXY EUROKOTE 468 THIXO LINING Issue no. DO27/PR3-24 - issue 2 Issue Date: 17/10/2022

Approval expiry date: 9 November 2025

Noksel Steel Pipe Co Inc

Noksel Steel Water Pipe - Coated with Thixo 468

56/4/1192

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: NOKSEL'S COATED AND LINED STEEL PIPES FOR THE TRANSPORTATION OF POTABLE WATER PIPES Issue no. NOK-DJM-INT-0001, Revision 3 Issue Date: 11/05/2023

Approval expiry date: 4 October 2025

Northpoint Ltd

J-Guard VA5001 pipes coated with Jotaguard VA5001

56/4/1511

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: J-GUARDVA5001.2017111011343.02 Issue no. 02 Issue Date: 10/10/2023

Approval expiry date: 9 October 2028

Pipes and fittings lined with Eurokote 468 Thixo

56/4/1209

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions of Use of pipes lined with Eurokote 468 Thixo Coating System. Issue No 2 rev1, Issue date 08/12/2020

Approval expiry date: 13 June 2026

Pipes, Fittings, Steelwork & Tank plates coated with Resicoat R4-FB

HKC71R

56/4/659

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Resicote R4-FB 20220802 Issue no. 0901 Issue Date: 15/09/2022

Approval specific to Resicoat R4-FB HKC71R

Approval expiry date: 13 November 2029

Powerrun Pipe-Mech Ltd

Powerrun Fabricated Coated Carbon Steel Pipework

56/4/1439

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document – Coated Pipework Issue no. PFCCSP Rev2 (3rd Issue) Issue Date: 11/01/2022

Approval expiry date: 26 June 2027

Soluciones Tubulares Sostenibles SL

Steel pipe coated with Eurokote 468 Thixo

56/4/1203

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: STEEL PIPE COATED WITH EUROKOTE 468 THIXO Issue no. 04 Issue Date: 04/04/2025

Approval expiry date: 10 May 2026

Specialist Protective Coatings Ltd

Eurokote 468 THIXO Brun Rouge-500

56/4/1389

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: High Performance Factory Applied lining of Potable Water Pipes Eurokote 468 Thixo Issue no. 02 Issue Date: 22/08/2024

Approval expiry date: 8 July 2026

UTS Engineering Ltd

Fabricated mild steel pipework coated with Jotaguard VA5001

56/4/1324

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pipes coated with Jotaguard VA5001 Instructions for use Document Issue no. 1 Issue Date: 01/02/2019

Approval expiry date: 14 August 2029

B.1.10 Stainless steel pipes

Aalco Metals Ltd (formerly Amari Metals Ltd)

Stainless Steel Tube, Stainless Steel pipe

56/4/738

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Tube, Stainless Steel Pipe & Stainless Steel Fittings Issue no. 5 Issue Date: 13/07/2023

Approval expiry date: 19 July 2026

ABC Stainless Ltd

ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels

56/4/542

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel "Q" Pipe System & Storage, Process Tanks and Vessels Issue no. 2 Issue Date: 20/10/2003

Approval expiry date: 12 December 2027

AJ Engineering and Construction Services Ltd

Stainless Steel Pipework and Fabrications

56/4/1220

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework and Fabrications for water use. Issue: WP 41, Issue date: 03/09/2021

Approval expiry date: 30 November 2026

Alpha Plus Ltd

Stainless Steel Pipework

56/4/1564

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework IFU Issue no. 3 Issue Date: 11/12/2024

Approval expiry date: 10 December 2029

Atom Fabs Ltd

Stainless steel fabrications: Tanks, Pipework, Support and Access Systems

56/4/1484

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU/DWI/56.4.AtomFabs Issue no. 1 Issue Date: 21/12/2022

Approval expiry date: 8 February 2028

Berry & Escott Engineering

Stainless Steel Pipework and Fabrications

56/4/1362

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Fabricated Pipework Issue no. F-3.4-04 Issue 1 Issue Date: 26/02/2019

Approval expiry date: 23 April 2029

Bridges Electrical Engineering Ltd

Bridges in-house fabricated stainless steel pipe spools and products

56/4/1268

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Bridges in-house fabricated stainless steel pipe spools and products Issue no. 1 Issue Date: 22/03/2017

Approval expiry date: 6 June 2027

BSS Industrial

Stainless Steel Tubings and Fittings

56/4/1017

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BSS INDUSTRIAL - METRIC, ISO STAINLESS IFU DOCUMENT Issue no. V2 Issue Date: 14/03/2022

Approval expiry date: 30 June 2027

DH Stainless Ltd

Stainless Steel Metric ISO & ANSI welded pipe and fittings

56/4/773

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Drinking Water Supply - Stainless Steel Piping Products Issue no. 1 Issue Date: 13/03/2020

Approval expiry date: 17 March 2030

Diamond Fabrication & Pipework Ltd

Diamond Fabricated pipework assemblies

56/4/1489

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Diamond Fabricators Stainless Steel Pipework Issue no. 001 Issue Date: 05/07/2023

Approval expiry date: 5 July 2028

Direct Engineering & Site Services Ltd

Stainless steel flanged pipes

56/4/1443

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Flanged Pipework Issue no. 01 Issue Date: 02/12/2021

Approval expiry date: 10 February 2027

EPS Group

Stainless Steel Tanks & Pipework

56/4/1267

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Tanks & Pipework, Issue no. 2 Issue Date: 01/03/2022

Approval expiry date: 16 October 2027

Equipdata Trading

IPSSSPW01 Stainless Steel Pipework and Fabrications

56/4/1316

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IPS Product Number IPSSSPW01 Issue no. 5 Issue Date: 25/04/2023

Approval expiry date: 5 July 2028

Fabcon Food Systems Ltd

Stainless Steel fabrications and pipework for water use

56/4/1466

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BESPOKE STAINLESS STEEL PIPE FABRICATED FOR WATER USE Issue no. 001 Issue Date: 27/05/2022

Approval expiry date: 22 June 2027

FSD Mech Ltd

Fabricated Stainless Steel Pipework

56/4/1455

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction For Use Fabricated Stainless Steel Pipework Issue no. 2 Issue Date: 08/08/2023

Approval expiry date: 27 July 2027

George Green (Keighley) Ltd

Stainless Steel Pipework & Fittings - Flanged/Screwed - All diameters & Grades

56/4/699

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework & Fittings – Plain Ended suitable for site welding / Flanged / Screwed – 12mm to 4000mm – For the conveyance and immersion in potable water Issue no. Issue No.6 Issue Date: 01/08/2024

Approval expiry date: 17 September 2029

Glasswell and Last Ltd

Stainless Steel Fabrications and Pipework

56/4/1474

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT Glasswell and Last Stainless Steel Products for use in the UK Public Water Supply System Issue no. 1.0 Issue Date: 21/09/2022

Approval expiry date: 21 November 2027

Homer Burgess Ltd

Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water

56/4/1107

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Homer Burgess Ltd – Manufacturers' official use instructions for Stainless Steel Products in contact with Drinking Water Issue no. 1 Issue Date: 26/01/2016

Approval expiry date: 5 July 2028

J.K Fabrications Limited

JKF 304 and 316 Stainless Steel Pipelines

56/4/574

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: JKF 304 & 316 Stainless Steel Pipelines Issue no. 4 Issue Date: 03/08/2018

Approval expiry date: 21 March 2029

JB Fabrication (Wrexham) Ltd

JBF Stainless Steel Pipework and Fabrications

56/4/1487

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: JB Fabrication Ltd Stainless Steel Pipework (DN15 to DN1000) and fabrications for Conveyance and immersion in Potable Water suitable for site welding, flanged or pressed fittings Issue no. 2 Issue Date: 10/09/2024

Approval expiry date: 6 June 2028

OSTP

OSTP Stainless Steel pipe and fittings of 12mm bore or greater.

56/4/516

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OSTP IFU Document issue 2 Issue no. 2 Issue Date: 08/02/2024

Approval expiry date: 31 October 2029

Panks Engineers Limited

Stainless Steel Fabrications and Pipework

56/4/1458

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless steel pipe fabrication for water intended for human consumption on Water industry sites Issue no. 1 Issue Date: 03/02/2022

Approval expiry date: 29 March 2027

Powerrun Pipe-Mech Ltd

Powerrun fabricated stainless steel pipework

56/4/769

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PFSSP Issue no. 6 Issue Date: 04/12/2024

Approval expiry date: 8 December 2029

Righton & Blackburns Ltd

Stainless Steel ANSI Metric ISO Pipe, Stainless Steel ANSI Metric ISO Tube, Stainless Steel ANSI Metric ISO Fittings

56/4/1462

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Issue no. 3 Issue Date: 07/03/2022

Approval expiry date: 26 February 2028

Ross-shire Engineering Ltd

Stainless steel process pipework systems

56/4/1034

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: TS/SW/001 Issue no. 4 Issue Date: 01/03/2021

Approval expiry date: 1 September 2026

Salt Separation Services Ltd

Pipework and tanks for use with drinking water

56/4/1477

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SSS-IFU-01 Pipes and Tanks Issue no. 4 Issue Date: 06/03/2023

Approval expiry date: 5 March 2028

Special Metric Materials Ltd

Tru Bore - Stainless Steel Tube and associated products

56/4/1465

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless steel welded tubular products Issue no. 1 Issue Date: 01/03/2023

Approval expiry date: 16 April 2028

Staptina Engineering Services Ltd

Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems

56/4/567

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Staptina Bespoke Stainless Steel Fabrications: Pipework, Baffles, Troughs, Tanks, Supports and Access Systems. Issue no. 24838IFU, issue 2 Issue Date: 02/02/2024

Approval expiry date: 10 March 2029

Veolia Water Technologies & Solutions (Hungary)

Stainless Steel Products

56/4/1371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Supply of Stainless Steel Piping, Tanks and other Equipment for use in the Public Water Supply in the UK by Veolia Water Technologies & Solutions Issue no. UKDWI/SSP/Revision 2 Issue Date: 17/06/2024

Only to be used with other Veolia Water Technologies & Solutions approved products.

Approval expiry date: 15 July 2029

Water Engineering Services Fabrication

Stainless Steel Pipework

56/4/1493

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Grade 316L Portable Water Pipework Issue no. WES156 Rev 3 Issue Date: 02/10/2023

Approval expiry date: 4 October 2028

Waveneys

Stainless Steel Fabrications and Pipework

56/4/1442

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Waveneys Stainless Steel Issue no. 1.0 Issue Date: 22/11/2021

Approval expiry date: 9 January 2027

Western Carbons Ltd

Stainless steel floor plates, weirs, pipework and tanks

56/4/1303

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel floor plates, weir extension plates, channel plates and pipework. Issue no. 1 Issue Date: 02/02/2023

Approval expiry date: 8 May 2028

B.1.11 Coated pipes suitable for total immersion in water

Freeflow Pipesystems Ltd

Fabricated Pipework and Fittings coated with Resicoat R4-FB HKC71R

56/4/817

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Fabricated Pipework and Fittings Coated with Resicoat R4-FB HKC71R Issue no. 11 Issue Date: 10/11/2022

Approval expiry date: 27 April 2030

B.2 Well Casings, Screens and Rising Mains

Angus Flexible Pipelines

Angus Wellmaster Flexible Rising Main

56/4/1020

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wellmaster Flexible Rising Main Issue no. 004 Issue Date: 01/09/2016

Prior to use the water supplier carries out a risk assessment to provide for a suitable flushing regime validated, where appropriate, by monitoring when the product has been out of supply for a period of time.

Approval expiry date: 19 December 2026

Boode UK Ltd

Boode Waterwell Systems Carbon Steel Casing & Screen

56/4/1525

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Boode Waterwell Systems Carbon Steel Screen and casing Issue no. 1 Issue Date: 28/11/2023

Approval expiry date: 1 February 2029

Boode Waterwell Systems PVC Screen and Casing

56/4/958

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Boode Waterwell Systems PVC Screen & Casing Issue no. 3
Issue Date: 01/07/2023

Approval expiry date: 9 August 2028

Cleveland Streel and Tubes Ltd

CST Water Well Casings

56/4/1430

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CST Water Well Casings Instructions for Use. Issue Date: 26/07/2021; Issue Number: 1

Approval expiry date: 31 August 2026

GOLAN Plastic Products Ltd

PEXGOL

56/4/1259

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pexgol X-Linked Borehole Piping Solution INSTRUCTIONS FOR USE & TECHNICAL INFORMATION Issue no. 01 Issue Date: 01/12/2016

Approval expiry date: 21 February 2028

Skapandi Ltd

Bore Hole Wellhead to Sub Pump Riser Pipe

56/4/1407

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SL-001-005-005-PC IFU - BORE HOLE WELLHEAD TO SUB PUMP RISER PIPE, Issue Date: 07/08/2020; Issue No.: 2

Approval expiry date: 29 December 2025

Mild Steel Well Casing

56/4/1429

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SL-001-005-010-PC IFU - MILD STEEL WELL CASING; Issue No 2; Dated: 07/06/2021

Approval expiry date: 9 June 2026

Stuwa-Konrad Stukerjurgan GmbH

Mild Steel Well Casting and Screens

56/4/1432

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU approval STUWA - Konrad Stukerjurgan GmbH Mild steel screens and casings; Issue Date: 5/27/2021; Issue No: 1

Approval expiry date: 25 July 2026

Stainless Steel Screens, Casings, Fittings and Accessories

56/4/1060

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless steel screens, casings, fittings and accessories Issue no. 4 Issue Date: 25/10/2021

Approval expiry date: 23 July 2027

STUWA Stainless Steel Riser Pipes

56/4/1077

Conditions of Approval: Use of the product must be in accordance with the Instructions for
Use: IFU approval STUWA - Konrad Stukerjurgan GmbH Issue no.
3 Issue Date: 01/06/2022

Approval expiry date: 31 May 2027

B.3 Products for Conveyance of Water -Emergency Use

For products in this section the following condition applies:

These products are primarily intended for emergency use and are approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

NOTE: some of these products may be suitable for limited use during planned maintenance. In this case it is the responsibility of the water supplier to undertake a thorough risk assessment of the proposed use, including fitness-for-purpose and why other products, already fully approved under the relevant regulations cannot be used. Use of any of these products during planned maintenance shall be in accordance with the condition set out above.

B.3.1 Hoses

Angus Flexible Pipelines

Angus Super Aquaduct

56/4/1005

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wellmaster Super Aquaduct Issue no. 006 Issue Date: 30/09/2016

– 1) After disinfection the product is flushed for its entire length before being brought into service. 2) When in use the main is kept continually in flow. 3) The product is primarily intended for emergency use and is approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from DWI should be sought before installation and use.

Approval expiry date: 19 December 2026

Langham Industrial Controls Ltd

BOUNDARY BOX ADAPTERS including Emergency Supply, and Regulatory Monitoring Flow & Pressure, and Pre

56/4/1420

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BOUNDARY BOX ADAPTERS including EMERGENCY SUPPLY AND REGULATORY MONITORING INSTRUCTION FOR USE Issue no. 2.5 Issue Date: 01/12/2020

The product is primarily intended for emergency use and are approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 1 January 2026

Parsch UK Limited

Aquaflex Layflat Hose

56/4/1397

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE (IFU) DOCUMENT AQUAFLEX LAYFLAT HOSE Issue no. PUK001 Issue Date: 01/04/2023
(i) after disinfection the product is flushed to waste for its entire length before being brought into service; (ii) when in use the main is kept continually in flow; (iii) the product is primarily intended for emergency use and is approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. The proposed use must not extend beyond a 90 day period of use on any one occasion.

Approval expiry date: 4 November 2026

B.3.2 Bowsers/tanks

Crossland Tankers Ltd

Tanks for transportation of drinking water

56/4/792

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Tank for Transporting drinking water. Issue 2 dated 30/3/15.

Approval expiry date: 25 November 2025

Water2U - Chard Truck Services

Water2U Tanker V1

56/4/1485

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Water2U Tanker V1 Issue no. 1 Issue Date: 22/02/2023
These products are primarily intended for emergency use and are approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 7 March 2028

Whale Tankers Ltd

Whale Drinking Water Bowser

56/4/662

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction For Use (IFU) - Whale Drinking Water Bowser Issue no. 03 Issue Date: 21/02/2024

Primarily intended for emergency use and are approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 7 December 2028

B.3.3 Liner bags

Arlington Packaging (Rental) Ltd

Arlington 1000 Litre Bag-in-Box Combo Liner

56/4/796

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Arlington 1000 Litre Water Tank Issue no. 4.2 Issue Date: 01/06/2020

This product is primarily intended for emergency use and is approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 5 August 2025

PART C LINING, COATINGS, SEALANT AND REPAIR MATERIALS

C.1 In-situ Installed (tubular) pipe linings

Aqualiner Ltd

Water Pipe Lining

56/4/910

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Water Pipe Lining. Version No 6, Issue Date: 01/04/2021

To be applied by authorised contractor

Approval expiry date: 6 November 2026

Public Sewer Services Limited

Wavin Compact Pipe

56/4/1417

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wavin Compact Pipe Issue no. 4 Issue Date: 01/03/2023

Curing after the reforming process must be undertaken for 24 hrs at a temperature no less than 7° C and return to service after an additional 48 hrs after setting required fix points.

Approval expiry date: 19 December 2028

C.2 In-situ applied Pipe Coatings

In-situ applied lining products approved for use by the Authorities for the relining of existing water mains/pipes must be applied in accordance with strict operational requirements as documented in the Water Industry Information & Guidance Note IGN 4-02-02 <http://www.water.org.uk/home/member-services/wis-and-ign/archived-documents/ign-4-02-02.pdf> "Code of Practice: In-situ resin lining of water mains" and the Water Industry Specification WIS 4-02-01 <http://www.water.org.uk/home/member-services/wis-and-ign/archived-documents/wis-4-02-01-v2.1---march-2009.pdf> "Operational Requirements: In situ resin lining of water mains".

The coatings listed in this section have been subject to review by DWI (including testing), on the basis of their proposed use with inert substrates such as metallic or cement based structures (or as specified in the manufacturer's Instructions for Use (IFU)), and upon the detailed application and curing requirements set out in the IFU. They have not been evaluated for any other aspect, such as fitness for purpose.

For use with other non-metallic non-cementitious materials, such as plastics, other coatings/linings, and rubbers, a specific application for approval would be required for use of the coating with a specific substrate.

C.2.2 Coatings based on polyurethane

These products must be applied by a certified contractor.

Radius Systems Ltd

Subcote FLP II

56/4/1286

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Radius Systems Subcote FLP II Product description and manufacturer's instructions for the in-situ lining of potable water mains Issue no. 7 Issue Date: 21/09/2021

This product must be cured for a minimum of 1 hour at a minimum temperature of 3°C.

Approval expiry date: 5 May 2030

Resimac Ltd

Resiline 320

56/4/1390

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IN-SITU RAPID SETTING POLYMERIC LINING OF POTABLE WATER MAINS Issue no. 4 Issue Date: 17/01/2022

(i) applied in accordance with WIS 4-02-01 and IGN 4-02-02; (ii) These products must be applied by a certified contractor; and (iii) The minimum cure time is one hour at a minimum temperature of 3°C

Approval expiry date: 17 January 2027

C.2.3 Coatings for small diameter pipes

This section covers pipes up to 75 mm internal diameter. The products listed in this section shall be applied by certified contractors in accordance with strict operational requirements as documented in the Water Industry Specification WIS 4-02-03 "Operational Requirements : In-situ polymeric lining of service pipes" (document is available from <https://www.water.org.uk/publications/WIS-IGN>)

Pipe Restoration Technologies LLC

ePipe UK

56/4/995

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IN-SITU HYDROPHOBIC POLYMERIC LINING OF POTABLE WATER SERVICE LINES Issue no. 11 Issue Date: 23/09/2022

This product shall be applied in accordance with strict operational requirements as documented in the Water Industry Specification WIS 4-02-03 "Operational Requirements: In-situ polymeric lining of service pipes" (document is available from <http://www.wis-ign.org>)

Approval expiry date: 28 September 2027

C.3 Site applied coatings for water retaining structures

The products listed below in this section, in addition to being approved for site applied coatings for water retaining structures, are suitable for use in large diameter mains where they can be applied by hand e.g. brush or spray.

The coatings listed in this section have been subject to review by DWI (including testing), on the basis of their proposed use with inert substrates such as metallic or cement based structures (or as specified in the manufacturer's Instructions for Use (IFU)), and upon the detailed application and curing requirements set out in the IFU. They have not been evaluated for any other aspect, such as fitness for purpose.

For use with other non-metallic non-cementitious materials, such as plastics, other coatings/linings, and rubbers, a specific application for approval would be required for use of the coating with a specific substrate.

C.3.1 Coatings based on epoxy resins

The following conditions apply unless otherwise indicated:

- (i) the minimum cure time is 16 hours; and
- (ii) the minimum cure temperature is 3°C.

Sika Ltd

Sikagard 62

56/4/197

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE Sikagard 62 Issue no. 2 Issue Date: 01/05/2012

The product must be cured in accordance with the cure curves provided in the Instructions for Use. The required cure time can be calculated by the user from the minimum daily temperature at the site of application. If the temperature cannot be measured and recorded then a minimum cure period of 21 days must be used.

Approval expiry date: 21 February 2028

C.3.2 Coatings based on polyurethane

Axalta Coating Systems

Acothane DW Blue

56/4/1059

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Acothane DW - A COATING AND LINING FOR WATER RETAINING STRUCTURES INCLUDING TANKS, VESSELS, RESERVOIRS, PIPELINES, PIPE RANDOM LENGTHS, BENDS, FITTINGS AND VALVES. Issue no. Issue 9 Issue Date: 02/12/2024

The product must be cured for a minimum period of 7 days at a minimum temperature of 3°C

Approval expiry date: 20 November 2029

Acothane DW Cream

56/4/1052

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Acothane DW - A COATING AND LINING FOR WATER RETAINING STRUCTURES INCLUDING TANKS, VESSELS, RESERVOIRS, PIPELINES, PIPE RANDOM LENGTHS, BENDS, FITTINGS AND VALVES. Issue no. Issue 9 Issue Date: 02/12/2024

The product must be cured for a minimum period of 7 days at a minimum temperature of 30C

Approval expiry date: 21 November 2029

Acothane LV Sealer

56/4/1058

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Acothane DW - A COATING AND LINING FOR WATER RETAINING STRUCTURES INCLUDING TANKS, VESSELS, RESERVOIRS, PIPELINES, PIPE RANDOM LENGTHS, BENDS, FITTINGS AND VALVES. Issue no. Issue 9 Issue Date: 02/12/2024

Product must be cured for a minimum of 3hrs at a minimum temperature of 30C, this product must then be overcoated with Acothane DW

Approval expiry date: 21 November 2029

Line-X LCC

Aquaurethane Extreme

56/4/874

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: LINE-X QUAURETHANE EXTREME Issue no. 7 Issue Date: 02/08/2016

The product must be cured for a minimum of 5 days at a minimum substrate temperature of 3° C and is only approved for use with concrete water retaining structures.

Approval expiry date: 1 January 2026

MBCC Construction Chemicals Limited

Sikalastic® M 808

56/4/1080

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sikalastic® M 808 Issue no. Rev 1 Issue Date: 25/06/2024
This product must be cured for a minimum of 7 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document.

Approval expiry date: 27 November 2029

C.4 Flexible covers and linings for water retaining structures

Note: Laminated flexible covers and linings for water retaining structures may not necessarily have been assessed for uses totally immersed in water, e.g. as baffles. For information on use see individual product Instructions for Use (IFU) document.

Power Plastics Ltd

Power Plas ® BC850 Baffle Curtain

56/4/1350

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PowerPlas BC850 Baffle Curtain - For use in water for human consumption Issue no. 2.0 Issue Date: 29/11/2024

Approval expiry date: 4 December 2029

PowerPlas ® TL850 Tank Liner

56/4/1385

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PowerPlas TL850 Tank Liner, Tank Liner - For use in water for human consumption Issue no. Issue 2.0 Issue Date: 09/12/2024
Product must be used upstream of final point of disinfection.

Approval expiry date: 15 January 2030

Sensor (UK) Ltd

Sensorline

56/4/1066

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE GEOMEMBRANES Issue no. 4.9 Issue Date: 09/11/2015

Approval expiry date: 16 February 2028

Soprema UK Ltd

Flagon Geo P/AT

56/4/856

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: FLAGON GEO P/AT MANUFACTURER'S OFFICIAL INSTRUCTIONS FOR USE (IFU) Issue no. 4 Issue Date: 24/07/2023

Approval expiry date: 19 September 2027

C.5 Cementitious coatings

Premcrete Ltd.

Premcrete Hydroseal FX

56/4/1356

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hydroseal FX Issue no. 05199 Issue Date: 01/03/2023
This product must be cured at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.
Hydroseal FX - Grey - Must be cured for a minimum of 21 days
Hydroseal FX - White - Must be cured for a minimum of 7 days
temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU
Approval expiry date: 20 November 2028

Premcrete Teknolevel FS

56/4/1359

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PremcreteTeknolevel FS Issue no. 01587 Issue Date: 31/01/2023
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU for any elevated temperatures.
Approval expiry date: 5 November 2025

Flexcrete Technologies Ltd

Cementitious Coating 851 White

56/4/1160

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Cementitious Coating 851 Issue no. 14 Issue Date: 01/01/2024
The White variant of this product must be cured for a minimum of 7 days at a minimum temperature of 7°C.
Approval expiry date: 27 October 2025

Cemprotec 851F

56/4/1340

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Cemprotec 851F Issue no. 4 Issue Date: 01/01/2024
This product must be cured for a minimum of 7 days at a minimum temperature of 7°C or in accordance with the manufacturers IFU.
Approval expiry date: 11 February 2029

International Paint Ltd

Intercrete 4841

56/4/1053

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4841 Issue no. 4841/031/011 Issue Date: 01/07/2020

The Grey product must be cured for a minimum of 21 days at a minimum temperature of 7°C and the White product must be cured for a minimum of 7 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

MBCC Construction Chemicals Limited

MasterSeal 581 with MasterSeal 600

56/4/1103

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 581 with MasterSeal 600 Issue no. CG/Rev4 Issue Date: 09/02/2024

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 27 February 2029

SikaTop®-581 Seal

56/4/1227

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SikaTop®-581 Seal APPLICATION TO POTABLE WATER CONTACT AREAS Issue no. CG/Rev1 Issue Date: 15/05/2024

This product must be cured for a minimum of 3 days at a minimum temperature of 3°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 30 June 2026

SikaTop®-588 Seal

56/4/1128

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SikaTop®-588 Seal APPLICATION TO POTABLE WATER CONTACT AREAS Issue no. CG/Rev 1 Issue Date: 15/05/2024

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 20 March 2029

Sika Ltd

SikaTop®-586 Seal

56/4/86

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SikaTop®-586 Seal with optional use of SikaLatex®-600 APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Issue no. Issue 2.0 Issue Date: 12/12/2024

Approval expiry date: 16 March 2030

Vandex isoliermittel-Gesellschaft m.b.H

VANDEX BB 75

56/4/1092

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vandex BB72 Issue no. 02 Issue Date: 04/11/2020

Approval expiry date: 18 September 2028

VANDEX SUPER

56/4/1098

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VANDEX SUPER Issue no. 2 Issue Date: 18/11/2020

Approval expiry date: 18 September 2028

VANDEX UNIMORTAR 1

56/4/1524

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vandex Unimortar 1 Issue no. 3 Issue Date: 23/11/2023

Approval expiry date: 17 January 2029

Xypex (UK) Ltd

Xypex Concentrate

56/4/1261

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Issue no. 0612C: XDS: Rev-04-16 Issue Date: 01/06/2021

Approval expiry date: 5 April 2027

Xypex Modified

56/4/1262

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Issue no. 0621M Issue Date: 01/06/2021

Approval expiry date: 18 September 2025

Xypex Patch'n Plug

56/4/1100

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Xypex (UK) Ltd – XYPEX PATCH'N PLUG – Instructions for Use Issue no. ISSUE NO: 0224P:XDS: Rev-06-21 Issue Date: 14/02/2024

Approval expiry date: 3 June 2029

C.6 Sealant & Repair Materials

Premcrete Ltd.

Premcrete Teknocem HB50

56/4/1357

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Premcrete Teknocem HB50 Issue no. 01553 Issue Date: 03/02/2023

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 5 March 2028

Premcrete Teknoprime 841

56/4/1360

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Teknoprime 841 Issue no. 015531 Issue Date: 01/02/2023

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 9 March 2028

Flexcrete Technologies Ltd

Cementitious Coating 851 Grey

56/4/1159

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Cementitious Coating 851 Issue no. 14 Issue Date: 01/01/2024

The Grey variant of this product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 27 October 2025

Fastfill

56/4/1162

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Fastfill Issue no. 12 Issue Date: 01/01/2024

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 27 October 2025

Monolevel 844SP

56/4/1161

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Monolevel 844SP Issue no. 12 Issue Date: 01/01/2024

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

Monomix

56/4/1163

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Monomix Issue no. 12 Issue Date: 01/01/2024
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 27 October 2025

Monomix WS

56/4/397

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Monomix WS Issue no. 12 Issue Date: 01/01/2024
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 27 October 2025

Steel Reinforcement Protector 841

56/4/1164

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Steel Reinforcement Protector 841 Issue no. 12 Issue Date: 01/01/2024
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 27 October 2025

Tiefill

56/4/1287

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Tiefill Issue no. 5 Issue Date: 01/01/2024
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

Fosroc International Ltd

Conbextra Bedding Mortar

56/4/1271

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Conbextra Bedding Mortar Issue no. BM1 Issue Date: 01/04/2017
This product must be cured for a minimum of 21 days at 7° C. ii) not to be used below 5° C.

Approval expiry date: 28 November 2027

Renderoc Plug 20

56/4/297

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RRP20 Issue no. 4 Issue Date: 01/05/2022
This product must be cured for a minimum of 7 days at a minimum temperature of 7°C as detailed in the manufacturer's Instructions for Use document.

Approval expiry date: 5 February 2028

International Paint Ltd

Intercrete 4800

56/4/1403

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4800
Issue no. 4800/031/010 Issue Date: 01/07/2020
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.
Approval expiry date: 1 January 2026

Intercrete 4800WS

56/4/1408

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4800WS
Issue no. 4800WS/031/010 Issue Date: 01/07/2020
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.
Approval expiry date: 27 October 2025

Intercrete 4802

56/4/1055

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use in Public Water Supply Intercrete 4802
Issue no. 4802/031/010 Issue Date: 01/07/2020
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.
Approval expiry date: 27 October 2025

Intercrete 4807

56/4/1404

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4807
Issue no. 4807/031/003 Issue Date: 01/07/2020
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.
Approval expiry date: 1 January 2026

Intercrete 4820

56/4/1054

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4820
Issue no. 4820/031/010 Issue Date: 01/07/2020
This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU
Approval expiry date: 27 October 2025

Intercrete 4871

56/4/1056

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4871 Issue no. 4871/031/009 Issue Date: 01/07/2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU.

Approval expiry date: 1 January 2026

Master Builders Solutions UK Ltd

MasterEmaco S420 with MasterSeal 600

56/4/1064

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterEmaco S420 with MasterSeal 600 IFU Issue no. CG/Rev 3 Issue Date: 18/06/2021

i) This product must be cured for a minimum of 3 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document. ii) Before connection to the supply, the water undertaker or their appointed agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations.

Approval expiry date: 27 February 2028

MBCC Construction Chemicals Limited

MasterSeal 930 with MasterSeal 933

56/4/144

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 930 with MasterSeal 933 Issue no. GC/Rev 4 Issue Date: 09/02/2024

This product must be cured for a minimum of 10 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 27 February 2029

MG Solutions (UK) Ltd

Aquron 2000

56/4/1291

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aquron 2000 Colloidal Silicate for waterproofing of concrete. Issue no. 1.2 Issue Date: 12/10/2020

Approval expiry date: 19 September 2027

Aquron 300®

56/4/1409

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aquron 300® IFU, Issue: 1.1, Issue Date: 17/08/2021

Product must be cured for a minimum of 72 hrs at a minimum temperature of 7°C in accordance with the manufacturer's IFU.

Approval expiry date: 6 September 2026

Aquron 7000

56/4/1410

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aquron 7000® Issue no. 1.1 Issue Date: 17/08/2020
Product must be cured for a minimum of 72 hrs at a minimum temperature of 3°C in accordance the manufacturers IFU.
Approval expiry date: 29 July 2026

Natural Cement Distribution Ltd

NATCEM 35

56/4/1090

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: NATCEM 35 Fast Setting and Fast Curing Issue no. 4 Issue Date: 21/02/2023
Product must be set and cured for a minimum of 240 minutes at a minimum temperature of 0°C in accordance with the manufacturer's Instruction for Use.
Approval expiry date: 10 March 2029

NATCEM AC

56/4/840

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Natcem AC Issue no. 4 Issue Date: 16/09/2024
Product must be set and cured for a minimum of 240 minutes at a minimum temperature of 0°C in accordance with the manufacturer's Instruction for Use
Approval expiry date: 19 January 2030

NATCEM D

56/4/1216

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DRY PRE-BLENDED GROUT NATCEM D Issue 2: Issue Date: 07/05/21
Approval expiry date: 27 December 2026

NATCEM DW

56/4/1049

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Natcem DW- Fast Setting Mortar Issue no. 2 Issue Date: 23/01/2023
Product must be cured for a minimum of 240 minutes at a minimum temperature of 7 °C, in accordance with the manufacturer's Instruction for Use.
Approval expiry date: 5 February 2028

Shotcrete 513

56/4/1089

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTION FOR USE FAST SETTING DRY SPRAY CONCRETE SHOTCRETE 513 Issue no. 2 Issue Date: 23/01/2023
Product must be cured for a minimum of 60 minutes at a minimum temperature of 7 °C, after setting has elapsed in accordance with the manufacturer's Instruction for Use.
Approval expiry date: 6 February 2028

Waterstop

56/4/1217

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: FAST SETTING NATURAL CEMENT WATERSTOP Issue: 3, Date: 07/05/2021

Approval expiry date: 27 December 2026

Sika Ltd

Sikadur Combiflex SG Jointing System, using Sikadur 31DW

56/4/94

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sikadur® Combiflex® SG Jointing System Issue no. 006 Issue Date: 01/10/2011

The minimum cure temperature is 7oC for a minimum cure time of 21 days. For temperatures greater than 7oC the product must be cured in accordance with the cure curve provided in the Instructions For Use and recorder at site of application.

Approval expiry date: 15 February 2027

Sikadur-Combiflex®-930 with Sikadur-Combiflex®-933

56/4/1569

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sikadur-Combiflex®-930 with Sikadur-Combiflex®-933 APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Issue no. 1 Issue Date: 23/09/2024

This product must be cured for a minimum of 10 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 5 December 2029

VIP-Polymers Limited

VIP-WECO HYBRID LINER UNIT

56/4/1479

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VIP-WECO HYBRID LINER UNIT Issue no. 4 Issue Date: 20/02/2024

The length of product installed should be in accordance with accepted IFU

Approval expiry date: 7 February 2028

Xypex (UK) Ltd

C-1000NF

56/4/1263

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: XYPEX ADMIX C-1000 NF Issue no. 0621A1 Issue Date: 01/06/2021

Approval expiry date: 5 April 2027

C500NF

56/4/1244

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE XYPEX ADMIX C-500 NF Issue no. 1223A5 Issue Date: 04/12/2023

Approval expiry date: 9 February 2029

PART D MEMBRANE AND FILTRATION SYSTEMS

For products in this section the following general condition applies:

Products must be installed upstream of any final point of disinfection.

D.1 Membrane and Filtration Elements/Systems

Amazon Filters Ltd

Amazon SupaSpun II Cartridge Filters

56/4/702

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Amazon Supagard and Supaspun II Issue no. 9 Issue Date: 25/02/2010

Approval expiry date: 11 August 2025

Amazon SupaSpun II Cartridge Filters

56/4/1596

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - Amazon Supagard and Supaspun II Filter Cartridges Issue no. Issue 9 Issue Date: 05/02/2010

Approval expiry date: 11 August 2025

DuPont Water Solutions (Speciality Electronic Materials UK Ltd)

Memcor CMF-L L10N

56/4/1254

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MEMCOR CMF-L L10N RANGE OF MICROFILTRATION SUBMODULES (PVDF MEMBRANES) Issue no. E Issue Date: 11/01/2024

Product must be installed upstream of any final point of disinfection

Approval expiry date: 18 January 2027

Memcor CMF-L L20N

56/4/1255

Conditions of Approval:

Product must be installed upstream of any final disinfection point

Approval expiry date: 18 January 2027

Memcor CMF-L L40N

56/4/1305

Conditions of Approval:

Product must be installed upstream of any final disinfection point

Approval expiry date: 18 January 2027

Memcor CMF-M10C Continuous Microfiltration Module (Polypropylene Membranes)

56/4/975

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF M10C CONTINUOUS MICROFILTRATION MODULE (POLYPROPYLENE MEMBRANES) Issue no. J Issue Date: 11/01/2024

Products must be installed upstream of any final point of disinfection

Approval expiry date: 18 January 2027

Memcor CMF-S S10N

56/4/1256

Conditions of Approval:

Product must be installed upstream of any final disinfection point

Approval expiry date: 18 January 2027

MEMCOR CMF-S S10T MICROFILTRATION SUBMODULE (SUBMERGED POLYPROPYLENE MEMBRANES) WITH OPTIONAL MEMCOR EF 56/4/976

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MEMCOR CMF-S S10T MICROFILTRATION SUBMODULE (SUBMERGED POLYPROPYLENE MEMBRANES) Issue no. K Issue Date: 11/01/2024

Products must be installed upstream of any final point of disinfection

Approval expiry date: 18 January 2027

Envirogen Group Ltd

Deltapor MW and MWA Filter Cartridges

56/4/1274

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ENVIROGEN DELTAPOR MW AND MWA FILTER CARTRIDGES Issue no. 3 Issue Date: 25/02/2021

Products must be installed upstream of any final point of disinfection

Approval expiry date: 4 May 2028

Mecana Umwelttechnik GmbH

Pile Cloth Media Filter (PCMF) DW2/10 - DW27/135

56/4/1215

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Application for a pile cloth filtration system in drinking water scope Filter types DW2/10 – DW27/135 Issue no. 5 Issue Date: 24/05/2019

Approval expiry date: 2 July 2028

Pile Cloth Media Filter (PCMF) DW2/10 to DW27/135 with UFS-9-DW cloth

56/4/1387

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Application for a pile cloth filtration system in drinking water scope Issue: 0 | Issue Date: 28 April 2021

Products must be installed upstream of any final point of disinfection

Approval expiry date: 10 May 2026

Nanostone Water Inc

CM-151™

56/4/1388

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CM-151™ Instructions for Use (IFU) Issue no. 3.0 Issue Date: 04/08/2022

Products must be installed upstream of any final point of disinfection

Approval expiry date: 15 August 2027

Pall International Sarl

Pall Microza UNA-620C microfiltration module

56/4/795

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use for membrane products in water supply - Instructions for use document for Pall Microza UNA-620C Micro-filtration modules, Issue number 3, Date of issue: 26 July 2006

Approval expiry date: 16 August 2025

PCI Membranes

C10 Module

56/4/234

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: C10 Module Issue no. J Issue Date: 01/11/2017
Product must be installed upstream of any final point of disinfection.

Approval expiry date: 30 January 2027

CA202 Membrane

56/4/76

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CA202 Membrane Issue no. K Issue Date: 01/11/2017
Product must be installed upstream of any final point of disinfection.

Approval expiry date: 30 January 2027

ES404 Membrane

56/4/215

Conditions of Approval:
Product must be installed upstream of any final point of disinfection.

Approval expiry date: 30 January 2027

PWNT Holding B. V.

CeraMac® Technology

56/4/1179

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CeraMac® Instructions For Use (IFU) by PWNT Holding B.V. Issue no. INT.GEN-GEN-5812-001 Revision 2.3 Issue Date: 14/03/2024

Approval expiry date: 17 January 2027

SUEZ Water Technologies and Solutions Hungary Kft

Ultrafiltration element ZW700B-8060/UF10/7B/X/0.8/40

56/4/1126

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: UKDWI/ZW700B-8060/Version 1, Date of issue: 08 January 2018

Approval expiry date: 19 January 2026

ZeeWeed® 700B-10060 Membrane Module

56/4/1398

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document For elements: ZW700B-10060/UF8/7B/S/0.9/60 ZW700B-10060/UF8/7B/V/0.9/60 ZW700B-10060/UF8/7B/T/0.9/60 Issue date: 18 June 2021; Issue No: UKDWI/ZW700B-10060-v3

Products must be installed upstream of any final point of disinfection

Approval expiry date: 12 January 2026

ZeeWeed® 700B-10072 (RMS)

56/4/1425

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document For elements: ZW700B-10072(RMS)/UF8/7B/S/0.9/85 Issue no. UKDWI/ZW700B-10072 (RMS) – V1 Issue Date: 14/06/2021

Product must be used upstream of final point of disinfection

Approval expiry date: 5 July 2026

Veolia Water Technologies & Solutions (Hungary)

ZeeWeed 1500 Series

56/4/1013

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 1500 Series Issue no. UKDWI/1500/Revision 9.0 Issue Date: 31/08/2023

Products must be installed upstream of any final point of disinfection

Approval expiry date: 25 February 2029

ZeeWeed 500D Module and Cassette; 500D (340, 370), 500D (440), 500Ds (350)

56/4/835

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use for the ZeeWeed® 500d (340), 500d (440), 500ds (350) Membrane Filtration Modules Issue no. UKDWI/500d Revision 10.0 Issue Date: 27/05/2024

Products must be installed upstream of any final point of disinfection

Approval expiry date: 21 February 2026

ZeeWeed 700B family of modules

56/4/1464

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document For element ZW700B-8060/UF10/7B/R/0.8/40 and ZW700B-8060/UF10/7B/X/0.8/40, Instructions for Use Document For element ZW700B-9060/UF10/7B/XA/0.8/55, Instructions for Use Issue no. UKDWI/ZW700B-8060/Version 2, UKDWI/ZW700B-9060 – V Issue Date: 10/09/2023

Products must be installed upstream of any final point of disinfection

Approval expiry date: 25 February 2029

Veolia Water Technologies & Solutions (USA)

Absolute.Za*DWI

56/4/1325

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Absolute.Za DWI* Issue no. UKDWI/ABS.Za DWI/Revision 1.1 Issue Date: 19/04/2023

Products must be installed upstream of any final point of disinfection

Approval expiry date: 25 February 2029

X-FLOW B.V.

HFW 1000

56/4/1139

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction For Use for HFW 1000 Issue no. version: 1.2 Issue Date: 15/10/2014

Product must be installed upstream of any final point of disinfection.

Approval expiry date: 29 September 2026

XF-series - modules XF40, XF40C, XF42 and XF 53

56/4/324

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use for X-Flow Membrane Filtration Elements Issue no. Version 8.0 Issue Date: 31/05/2021

Product must be installed upstream of any final point of disinfection

Approval expiry date: 18 August 2025

XF-series - modules XF55, XF64 and XF75

56/4/967

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use for X-Flow Membrane Filtration Elements Issue no. Version 8.0 Issue Date: 31/05/2021

Products must be installed upstream of any final point of disinfection

Approval expiry date: 18 August 2025

D.2 Vessels and Containers for Membrane and Filtration Elements

Amazon Filters Ltd

Single and Multiple Cartridge & Bag Filter Housings and Interconnecting pipework

56/4/879

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Amazon Single and Multiple Cartridge & Bag Filter Housings and Interconnecting Pipework: INSTRUCTIONS FOR USE IN DRINKING WATER SYSTEMS. Issue 2 November 2016

Approval expiry date: 11 August 2025

Eliquo Hydrok

Eliquo Hydrok Filter Housing Tank

56/4/1386

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Eliquo Hydrok Filter Housing Tank I.F.U. Issue no. Version 2.0 Issue Date: 25/10/2024

Approval expiry date: 6 January 2030

Envirogen Group Ltd

Envirogen CF Filter Housing

56/4/1257

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ENVIROGEN CF FILTER HOUSING Issue date: 25/02/2021 Issue number: 3

Product must be installed upstream of any final point of disinfection.

Approval expiry date: 12 March 2027

Filedor Filter Systems Ltd

INOX EFH, SFH PFH PSFH,PFH-SGB Stainless Steel Filter Housings

56/4/1191

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Spectrum INOX Stainless Steel Housing Range, Issue: 1 , Issue Date: 17/05/2021

Product must be installed upstream of any final point of disinfection

Approval expiry date: 30 November 2026

INOX SBH,PBH Stainless Steel Bag Housings

56/4/848

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Spectrum INOX Stainless Steel Housing Range, Issue: 1, Issue Date: 17/05/2021

Product must be installed upstream of any final point of disinfection

Approval expiry date: 30 November 2026

Pentair Water India Pvt Ltd

CodeLine RO membranes

56/4/288

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for use CodeLine® OCTA Series Side Ported Membrane Housings MODEL - 80S Issue no. 94182-Rev B Issue Date: 01/01/2022

Product must be installed upstream of any final point of disinfection

Approval expiry date: 18 July 2027

D.4 Filter Media Containing Systems

Dynamik Filtr Nocon i Wspólnicy Spółka jawna

PRESSURE FILTRATION KIT DF FP/FDN 800÷3 500

56/4/1272

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PRESSURE FILTRATION KIT DF FP/FDN 800 ÷ 3 500 Issue no. FP/FDN 800÷3 500/001/17/IFU Issue Date: 02/11/2022

Approval expiry date: 30 March 2028

Hydro-Gen Engineering Ltd

Velocitek OVF Filter Vessel

56/4/1400

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use Velocitek OVF Filter Vessel. Issue Date: 14.04.2020; Version No. 2

Approval expiry date: 28 July 2025

Nijhuis Saur Industries (UK & Ireland)

Continuous Sand Filter

56/4/1521

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: OM-HR i-CSF-Nijhuis-EN_D0125299 Issue no. Rev A Issue Date: 02/03/2021

Approval expiry date: 30 October 2029

PART E OTHER WATER TREATMENT WORKS INSTALLATIONS

E.1 Tanks

ABC Stainless Ltd

ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels

56/4/542

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel "Q" Pipe System & Storage, Process Tanks and Vessels Issue no. 2 Issue Date: 20/10/2003

Approval expiry date: 12 December 2027

Allied Storage Tank Ltd

Stainless Steel Tanks and Launderers

56/4/1258

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date: 30/01/2017 Issue No.1

Approval expiry date: 26 February 2027

Atom Fabs Ltd

Stainless steel fabrications: Tanks, Pipework, Support and Access Systems

56/4/1484

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU/DWI/56.4.AtomFabs Issue no. 1 Issue Date: 21/12/2022

Approval expiry date: 8 February 2028

Barr + Wray Ltd

Barr + Wray Stainless Steel Filter Media

56/4/1234

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Stainless Steel Media Filter Issue no. 2 Issue Date: 01/11/2021

Approval expiry date: 10 January 2027

Berry & Escott Engineering

Stainless Steel Pipework and Fabrications

56/4/1362

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Fabricated Pipework Issue no. F-3.4-04 Issue 1 Issue Date: 26/02/2019

Approval expiry date: 23 April 2029

EPS Group

Stainless Steel Tanks & Pipework

56/4/1267

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Tanks & Pipework, Issue no. 2 Issue Date: 01/03/2022

Approval expiry date: 16 October 2027

Equipdata Trading

IPSSSPW01 Stainless Steel Pipework and Fabrications

56/4/1316

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IPS Product Number IPSSSPW01 Issue no. 5 Issue Date: 25/04/2023

Approval expiry date: 5 July 2028

Forbes Technology Ltd

Cheetah range of Tanks & Towers

56/4/1292

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QA379 - Cheetah Range Issue no. 7 Issue Date: 22/09/2022

Approval expiry date: 9 January 2028

Jaguar Range of Storage & Process Tanks & Towers

56/4/1210

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HANDLING, INSTALLATION AND COMMISSIONING INSTRUCTIONS FOR THE FORBES JAGUAR RANGE OF STORAGE & PROCESS TANKS & TOWERS Issue No: QA427 Rev 03; Issue Date: 28-01-2021

Approval expiry date: 19 October 2026

Lion Range of Tanks & Towers

56/4/1293

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QA378-Lion Range Issue no. 07 Issue Date: 02/09/2022

Approval expiry date: 8 December 2027

Glasswell and Last Ltd

Stainless Steel Fabrications and Pipework

56/4/1474

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT Glasswell and Last Stainless Steel Products for use in the UK Public Water Supply System Issue no. 1.0 Issue Date: 21/09/2022

Approval expiry date: 21 November 2027

Homer Burgess Ltd

**Tanks and associated Pipework, Weir Plates and Baffle Plates
manufactured from Stainless steel suitable for use with drinking water**

56/4/1107

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Homer Burgess Ltd – Manufacturers' official use instructions for Stainless Steel Products in contact with Drinking Water Issue no. 1 Issue Date: 26/01/2016

Approval expiry date: 5 July 2028

Permastore Ltd

Fusion ® V1100

56/4/1214

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use and Installation of FUSION® V1100 Tanks for the Storage of Water, Issue: P284 - Revision 2, Issue Date: 15/03/21

Approval expiry date: 19 December 2026

PERMASTORE STAINLESS STEEL

56/4/594

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Permastore Stainless Steel Tanks Issue no. P236 Rev 4 Issue Date: 25/10/2024

Approval expiry date: 11 April 2026

Trifusion ®

56/4/1213

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use and Installation of TRIFUSION® Tanks for the Storage of Water , Issue: P285 - Revision 2, Issue Date: 15/03/21

Approval expiry date: 19 December 2026

Powerrun Pipe-Mech Ltd

Stainless Steel Grade 316L Potable Water Reservoir Tanks

56/4/611

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Grade 316L Potable Water reservoir Tank Issue no. PWRT (PP-ML) Rev 2 Issue Date: 06/06/2023

Approval expiry date: 12 September 2028

PWNT Holding B. V.

CeraMac Backwash Vessel

56/4/1548

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CeraMac® Backwash Vessel - INT.GEN-GEN-5818-001 Issue no. C Issue Date: 13/07/2024

Approval expiry date: 3 March 2030

In-Line Coagulation and Adsorption (ILCA)

56/4/1557

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: In-line Coagulation and Adsorption System for use with CeraMac Issue no. INT-GEN-GEN-5815-001- A Issue Date: 13/07/2024

Approval expiry date: 30 March 2030

Ross-shire Engineering Ltd

Stainless Steel Water Tanks

56/4/1381

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Drinking Water Stainless Steel Water Tanks TS/SW/002 Issue no. 2 Issue Date: 28/10/2024

Approval expiry date: 8 December 2029

Salt Separation Services Ltd

Pipework and tanks for use with drinking water

56/4/1477

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SSS-IFU-01 Pipes and Tanks Issue no. 4 Issue Date: 06/03/2023

Approval expiry date: 5 March 2028

Sayers Road Tankers Ltd

Stainless Steel Water Tanks

56/4/1028

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Water Tanks Issue no. 3 Issue Date: 21/01/2021

Approval expiry date: 8 August 2026

SDS Pipe Systems Ltd

Weholite Pipe and Panels

56/4/513

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Weholite HDPE Tanks (Pipes and Panels) & Weholite HDPE Pipes Issue no. 6 Issue Date: 06/10/2022

Approval expiry date: 10 November 2027

Silotank (Digestors, Silos & Tanks) Ltd

Leinster Range of Thermoplastic Tanks

56/4/498

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use Manual FOR LEINSTER RANGE OF TANKS & TOWERS FOR DRINKING WATER & RAW WATER TO BE TREATED FOR DRINKING PURPOSE. Issue no. 7 Issue Date: 19/12/2024

Approval expiry date: 17 March 2030

Staptina Engineering Services Ltd

Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems

56/4/567

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Staptina Bespoke Stainless Steel Fabrications: Pipework, Baffles, Troughs, Tanks, Supports and Access Systems. Issue no. 24838IFU, issue 2 Issue Date: 02/02/2024

Approval expiry date: 10 March 2029

STORTEC Engineering Limited

Ultrastore Tank System

56/4/1456

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ULTRASTORE Tank System Issue no. 01 Issue Date: 22/06/2022

Approval expiry date: 26 June 2027

Veolia Water Technologies & Solutions (Hungary)

Stainless Steel Products

56/4/1371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Supply of Stainless Steel Piping, Tanks and other Equipment for use in the Public Water Supply in the UK by Veolia Water Technologies & Solutions Issue no. UKDWI/SSP/Revision 2 Issue Date: 17/06/2024

Only to be used with other Veolia Water Technologies & Solutions approved products.

Approval expiry date: 15 July 2029

Waveneys

Stainless Steel Fabrications and Pipework

56/4/1442

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Waveneys Stainless Steel Issue no. 1.0 Issue Date: 22/11/2021

Approval expiry date: 9 January 2027

Wefco (Gainsborough) Ltd.

Atmospheric Tanks & Pressure Vessels

56/4/1500

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Fabricated Atmospheric Tanks and Pressure Vessels Issue no. 1 Issue Date: 24/06/2023

Approval expiry date: 9 August 2028

Western Carbons Ltd

Stainless steel floor plates, weirs, pipework and tanks

56/4/1303

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel floor plates, weir extension plates, channel plates and pipework. Issue no. 1 Issue Date: 02/02/2023

Approval expiry date: 8 May 2028

E.2 Underdrains

For some products, including underdrains, Section 3.4 of Advice Sheet 7 indicates that products constructed from clay can be used without approval subject to the water supplier carrying out a risk assessment for suitability of the product and its possible impact on drinking water quality

Binnies UK Ltd

K Filter Floor

56/4/833

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Installation & Test Procedure for K-Type Filter Floors
Document Ref: SSD 019 - Issue: M - Issue Date: 14/07/2021

Approval expiry date: 3 November 2025

De Nora Water Technologies UK Services Ltd

Tetra LP Block System

56/4/522

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use for LP Block Underdrain System Issue no. 4 Issue Date: 20/09/2020

Approval expiry date: 8 February 2028

Plasmor Ltd

Plasmor U Blocks

56/4/988

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PLASMOR U BLOCKS Issue no. 4 Issue Date: 16/02/2022

Approval expiry date: 4 April 2027

Xylem Water Solutions Zelienople LLC

Leopold Type S / SL Underdrain and I.M.S. 200 Media Retainer, I.M.S. 1000 Media Retainer, I.M.S. Cap

56/4/1467

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type S®/SL® Underdrain Instruction for Use Issue no. TSLU-IFU-R04, Issue R04 Issue Date: 24/05/2022

Approval expiry date: 22 June 2027

Leopold Type SL Underdrain and I.M.S. Cap

56/4/371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type S®/SL® Universal Flume Instruction for Use Document TSLU-IFU-04 Issue no. R04 Issue Date: 18/03/2022

Approval expiry date: 24 April 2027

Leopold Type XA Underdrain and I.M.S. 200 Media Retainer, I.M.S. 1000 Media Retainer, I.M.S. Cap

56/4/1468

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type XA™ Underdrain Instruction for Use Issue no. TXU-IFU-R00, Issue R04 Issue Date: 24/05/2022

Approval expiry date: 22 June 2027

E.3 Pressure vessels

A.W.E. (Anderson Water Equipment) Limited

Pressure Vessels & Stainless Steel Pipework

56/4/1533

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PRESSURE VESSELS AND STAINELSS STEEL PIPEWORK
Issue no. 001 Issue Date: 21/12/2023

Approval expiry date: 25 February 2029

Abbott & Co (Newark) Ltd

Abbott Stainless Steel Pressure Vessels

56/4/1494

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Abbott Stainless Steel Pressure Vessels up to 100,000 L Issue no. 001 Issue Date: 15/03/2023

Approval expiry date: 6 June 2028

Barr + Wray Ltd

Barr + Wray Stainless Steel Filter Media

56/4/1234

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Stainless Steel Media Filter Issue no. 2 Issue Date: 01/11/2021

Approval expiry date: 10 January 2027

Charlatte Reservoirs

Hydrochoc Butyl Bladder Surge Vessel

56/4/1016

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: COMMISSIONING GENERAL INSTRUCTIONS Issue no. 3 Issue Date: 04/08/2021

Approval expiry date: 9 May 2027

CPE Pressure Vessels

CPE Pressure Vessels-304L and 316L Stainless Steel

56/4/1135

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CPE PRESSURE VESSELS FOR DRINKING WATER Issue no. IFU-01 Rev D Issue Date: 21/03/2024

Approval expiry date: 21 March 2029

PWNT Holding B. V.

CeraMac Backwash Vessel

56/4/1548

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CeraMac® Backwash Vessel - INT.GEN-GEN-5818-001 Issue no. C Issue Date: 13/07/2024

Approval expiry date: 3 March 2030

In-Line Coagulation and Adsorption (ILCA)

56/4/1557

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: In-line Coagulation and Adsorption System for use with CeraMac Issue no. INT-GEN-GEN-5815-001- A Issue Date: 13/07/2024

Approval expiry date: 30 March 2030

Quantum Engineering Developments Ltd

Quantum Pressure Vessels- 304L

56/4/1132

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QUANTUM PRESSURE VESSELS FOR DRINKING WATER IFU01 Issue no. D Issue Date: 04/03/2024

Approval expiry date: 20 May 2029

Quantum Pressure Vessels- 316L

56/4/1133

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QUANTUM PRESSURE VESSELS FOR DRINKING WATER IFU01 Issue no. D Issue Date: 04/03/2024

Approval expiry date: 17 April 2029

Salt Separation Services Ltd

Pipework and tanks for use with drinking water

56/4/1477

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SSS-IFU-01 Pipes and Tanks Issue no. 4 Issue Date: 06/03/2023

Approval expiry date: 5 March 2028

Wefco (Gainsborough) Ltd.

Atmospheric Tanks & Pressure Vessels

56/4/1500

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Fabricated Atmospheric Tanks and Pressure Vessels Issue no. 1 Issue Date: 24/06/2023

Approval expiry date: 9 August 2028

E.4 Other Products used for the treatment of water

Aalco Metals Ltd (formerly Amari Metals Ltd)

Stainless Steel Tube, Stainless Steel pipe

56/4/738

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Tube, Stainless Steel Pipe & Stainless Steel Fittings Issue no. 5 Issue Date: 13/07/2023

Approval expiry date: 19 July 2026

ABC Stainless Ltd

ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels

56/4/542

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel "Q" Pipe System & Storage, Process Tanks and Vessels Issue no. 2 Issue Date: 20/10/2003

Approval expiry date: 12 December 2027

AJ Engineering and Construction Services Ltd

Stainless Steel Pipework and Fabrications

56/4/1220

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework and Fabrications for water use. Issue: WP 41, Issue date: 03/09/2021

Approval expiry date: 30 November 2026

AMCON Europe s.r.o

VOLUTE DUO Dewatering Press and optional Inline Mixer

56/4/1471

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VOLUTE DUO Dewatering Press DW series Instruction Manual AND Inline Mixer (Dynamic Mixer/Static Mixer) DM/SM Series Instruction Manual Issue no. 1.1 AND 1.0 Issue Date: 01/11/2022

Approval expiry date: 17 August 2028

Atom Fabs Ltd

Stainless steel fabrications: Tanks, Pipework, Support and Access Systems

56/4/1484

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU/DWI/56.4.AtomFabs Issue no. 1 Issue Date: 21/12/2022

Approval expiry date: 8 February 2028

Berry Global

Geo Textile Terram T700

56/4/1344

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use of Terram T700 for Installation in Slow Sand Filters, Issue Date: 06/03/2016; Issue No: V.3

Approval expiry date: 25 October 2025

Bridges Electrical Engineering Ltd

Bridges in-house fabricated stainless steel pipe spools and products

56/4/1268

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Bridges in-house fabricated stainless steel pipe spools and products Issue no. 1 Issue Date: 22/03/2017

Approval expiry date: 6 June 2027

Colloide Engineering Systems Ltd

Lamella Separator Package (LSF)

56/4/1172

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE MANUAL LAMELLA SEPARATOR PACKAGE Issue no. DOCUMENT REF: 90002-1502 B Issue Date: 10/02/2015

Approval expiry date: 6 May 2030

ENEXIO 2H Water Technologies Ltd

TUBEdek FS41.50/84 PP

56/4/878

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use _ TUBEdek FS41_ January 2019 Ver 2.0 020119 Issue no. 2.0 January 2019 Issue Date: 01/01/2019

Approval expiry date: 12 December 2027

Equipdata Trading

IPSSSPW01 Stainless Steel Pipework and Fabrications

56/4/1316

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IPS Product Number IPSSSPW01 Issue no. 5 Issue Date: 25/04/2023

Approval expiry date: 5 July 2028

Evergreen Water Solutions

GreenPro Lamella Plate Settler

56/4/1501

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: GreenPro Lamella Plate Settler IFU Issue no. 1 Issue Date: 25/05/2023

Approval expiry date: 25 February 2029

Forbes Technology Ltd

Cheetah Tower Packings

56/4/711

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QA412 - Cheetah Pall Rings - Instructions for Use Manual Issue no. 6 Issue Date: 07/03/2019

Approval expiry date: 31 October 2029

Glasswell and Last Ltd

Stainless Steel Fabrications and Pipework

56/4/1474

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT Glasswell and Last Stainless Steel Products for use in the UK Public Water Supply System Issue no. 1.0 Issue Date: 21/09/2022

Approval expiry date: 21 November 2027

Homer Burgess Ltd

Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water

56/4/1107

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Homer Burgess Ltd – Manufacturers' official use instructions for Stainless Steel Products in contact with Drinking Water Issue no. 1 Issue Date: 26/01/2016

Approval expiry date: 5 July 2028

Huber Technology

Pressure-Tight Doors (TT7.1, TT7.Z, TT7.R and TT7.30)

56/4/1445

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) HUBER pressure-tight doors TT7 TT7.1 / TT7.Z / TT7.R / TT7.30 Issue no. 1 Issue Date: 22/12/2021

Approval expiry date: 1 March 2028

Jacopa Ltd

Jacopa Ltd / Nordic Water Lamella Plate Separators

56/4/622

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE OF THE JACOPA LIMITED / NORDIC WATER LAMELLA PLATE SEPARATORS Issue no. 2 Issue Date: 30/06/2023

Approval expiry date: 13 September 2028

Stainless Steel DAF

56/4/1180

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Dissolved Air Flotation – Jacopa DAF, Document number: DWIR31-2014-01, Issue: 01, Issue Date: 10/03/2020

Approval expiry date: 14 January 2026

Nijhuis Water Technology B.V.

IPF, ICF and NPF model of Dissolved Air Flotation units

56/4/620

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flotation units, IPF & NPF/NPF-HX Issue no. A Issue Date: 12/05/2025

Approval expiry date: 12 May 2030

Pontoon Work Ltd

Modular Pontoon

56/4/1309

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pontoonworks: pontoon solutions for working on clean water sites Issue no. 5 Issue Date: 19/09/2023

This product is approved for limited use during planned maintenance and may not be permanently installed. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use. NOTE: It is the responsibility of the water supplier to undertake a thorough risk assessment of the proposed use, including fitness-for-purpose. Use of this product during planned maintenance shall be in accordance with the condition set out above.

Approval expiry date: 31 October 2028

PWNT Holding B. V.

In-Line Coagulation and Adsorption (ILCA)

56/4/1557

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: In-line Coagulation and Adsorption System for use with CeraMac Issue no. INT-GEN-GEN-5815-001- A Issue Date: 13/07/2024

Approval expiry date: 30 March 2030

Suspended Ion Exchange (SIX)

56/4/1171

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SIX® Instructions For Use (IFU) by PWNT Holding B.V. Issue no. INT.GEN-GEN-5813-001 Revision 1.8 Issue Date: 14/03/2024

Approval expiry date: 13 October 2025

Sensor (UK) Ltd

Sensorline

56/4/1066

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE GEOMEMBRANES Issue no. 4.9 Issue Date: 09/11/2015

Approval expiry date: 16 February 2028

Special Metric Materials Ltd

Tru Bore - Stainless Steel Tube and associated products

56/4/1465

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless steel welded tubular products Issue no. 1 Issue Date: 01/03/2023

Approval expiry date: 16 April 2028

Staptina Engineering Services Ltd

Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems 56/4/567

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Staptina Bespoke Stainless Steel Fabrications: Pipework, Baffles, Troughs, Tanks, Supports and Access Systems. Issue no. 24838IFU, issue 2 Issue Date: 02/02/2024

Approval expiry date: 10 March 2029

Veolia Water Technologies & Solutions (Hungary)

Stainless Steel Products 56/4/1371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Supply of Stainless Steel Piping, Tanks and other Equipment for use in the Public Water Supply in the UK by Veolia Water Technologies & Solutions Issue no. UKDWI/SSP/Revision 2 Issue Date: 17/06/2024

Only to be used with other Veolia Water Technologies & Solutions approved products.

Approval expiry date: 15 July 2029

Vessco Engineering Ltd

Stainless Steel Vessels 56/4/1539

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use for Stainless Steel Products in contact with drinking water Issue no. 2 Issue Date: 27/02/2024

Approval expiry date: 29 July 2029

VIP-Polymers Limited

VIP-WECO Stainless Steel Tension Bands 56/4/1481

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MANUFACTURER'S OFFICIAL INSTRUCTIONS FOR USE "VIP-WECO stainless steel retaining tension bands" Issue no. 1 Issue Date: 14/11/2022

Approval expiry date: 5 April 2028

Waterfront Fluid Controls Ltd

Stainless Steel Penstock 56/4/1531

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Waterfront Stainless Steel Penstock Catalogue Issue no. SIOM-SS-SG-M/E-181 RevA Issue Date: 15/01/2021

Approval expiry date: 9 January 2029

Waveneys

Stainless Steel Fabrications and Pipework 56/4/1442

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Waveneys Stainless Steel Issue no. 1.0 Issue Date: 22/11/2021

Approval expiry date: 9 January 2027

Western Carbons Ltd

Stainless steel floor plates, weirs, pipework and tanks

56/4/1303

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel floor plates, weir extension plates, channel plates and pipework. Issue no. 1 Issue Date: 02/02/2023

Approval expiry date: 8 May 2028

Xylem Water Solutions Zelenopole LLC

Leopold Air Scour System

56/4/1250

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Leopold® Air Scour System AHP-IFU-00 Issue no. Issue: R01 Issue Date: 13/12/2016

Approval expiry date: 28 February 2027

Rivertex UK Ltd

Rivertex® APO850 PowerPlas (Grey)

56/4/1532

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Rivertex® APO850 IFU Issue no. REV2 Issue Date: 09/05/2024

Listed in Annex 3D of the list of approved products

Approval expiry date: 8 October 2029

INDEX BY PRODUCT NAME

List of approved products for use in public water supply in the United Kingdom

Steel Water Pipes line with epoxy coating Eurokote 468 Thixo	Erciyas Celik Boru Sanayi A.S	B.1.9	56/4/1001
Abbott Stainless Steel Pressure Vessels	Abbott & Co (Newark) Ltd	E.3	56/4/1494
ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels	ABC Stainless Ltd	B.1.10	56/4/542
ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels	ABC Stainless Ltd	E.1	56/4/542
ABC Stainless Steel Ltd Q Pipe System & Storage, Process Tanks and Vessels	ABC Stainless Ltd	E.4	56/4/542
Absolute.Za*DWI	Veolia Water Technologies & Solutions (USA)	D.1	56/4/1325
Abulox	EFT Holdings AG	A.9	56/4/1491
Acothane DW Blue	Axalta Coating Systems	C.3.2	56/4/1059
Acothane DW Cream	Axalta Coating Systems	C.3.2	56/4/1052
Acothane LV Sealer	Axalta Coating Systems	C.3.2	56/4/1058
AFM Activated Filter Media	Dryden Aqua Ltd	A.10	56/4/382
Airophos 750PWG	Airedale Chemical Company Ltd	A.9	56/4/960
Amazon SupaSpun II Cartridge Filters	Amazon Filters Ltd	D.1	56/4/702
Amazon SupaSpun II Cartridge Filters	Amazon Filters Ltd	D.1	56/4/1596
Angus Super Aquaduct	Angus Flexible Pipelines	B.3.1	56/4/1005
Angus Wellmaster Flexible Rising Main	Angus Flexible Pipelines	B.2	56/4/1020
Aquaclear ESOL Disinfection System	Bridge Biotechnology Ltd	A.7.2	56/4/1406
Aquaflex Layflat Hose	Parsch UK Limited	B.3.1	56/4/1397
Aquaurethane Extreme	Line-X LCC	C.3.2	56/4/874
Aquron 2000	MG Solutions (UK) Ltd	C.6	56/4/1291
Aquron 300®	MG Solutions (UK) Ltd	C.6	56/4/1409
Aquron 7000	MG Solutions (UK) Ltd	C.6	56/4/1410
Arlington 1000 Litre Bag-in-Box Combo Liner	Arlington Packaging (Rental) Ltd	B.3.3	56/4/796
Atmospheric Tanks & Pressure Vessels	Wefco (Gainsborough) Ltd.	E.1	56/4/1500
Atmospheric Tanks & Pressure Vessels	Wefco (Gainsborough) Ltd.	E.3	56/4/1500
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 141204	Barr + Wray Ltd	A.3.1	56/4/1238
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 200613	Barr + Wray Ltd	A.3.1	56/4/1239
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 341817	Barr + Wray Ltd	A.3.1	56/4/1237

List of approved products for use in public water supply in the United Kingdom

Barr + Wray Stainless Steel Filter Media	Barr + Wray Ltd	E.1	56/4/1234
Barr + Wray Stainless Steel Filter Media	Barr + Wray Ltd	E.3	56/4/1234
Betzdearborn DCL32	Veolia Water Technologies & Solutions	A.9	56/4/1505
Black PE80 Polyethylene Pipes	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/968
Black PE80 Polyethylene Pipes (ME3440)	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/986
Blue PE80 Polyethylene Pipes	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/970
Blue PE80 Polyethylene Pipes (PC002 50R698)	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/1120
Boode Waterwell Systems Carbon Steel Casing & Screen	Boode UK Ltd	B.2	56/4/1525
Boode Waterwell Systems PVC Screen and Casing	Boode UK Ltd	B.2	56/4/958
Bore Hole Wellhead to Sub Pump Riser Pipe	Skapandi Ltd	B.2	56/4/1407
BOUNDARY BOX ADAPTERS including Emergency Supply, and Regulatory Monitoring Flow & Pressure, and Pre	Langham Industrial Controls Ltd	B.3.1	56/4/1420
Bridges in-house fabricated stainless steel pipe spools and products	Bridges Electrical Engineering Ltd	B.1.10	56/4/1268
Bridges in-house fabricated stainless steel pipe spools and products	Bridges Electrical Engineering Ltd	E.4	56/4/1268
C10 Module	PCI Membranes	D.1	56/4/234
C-1000NF	Xypex (UK) Ltd	C.6	56/4/1263
C500NF	Xypex (UK) Ltd	C.6	56/4/1244
CA202 Membrane	PCI Membranes	D.1	56/4/76
Cementitious Coating 851 Grey	Flexcrete Technologies Ltd	C.6	56/4/1159
Cementitious Coating 851 White	Flexcrete Technologies Ltd	C.5	56/4/1160
Cemprotec 851F	Flexcrete Technologies Ltd	C.5	56/4/1340
Centraltubi	Centraltubi SPA	B.1.1	56/4/913
CeraMac Backwash Vessel	PWNT Holding B. V.	E.1	56/4/1548
CeraMac Backwash Vessel	PWNT Holding B. V.	E.3	56/4/1548
CeraMac® Technology	PWNT Holding B. V.	D.1	56/4/1179
Cheetah range of Tanks & Towers	Forbes Technology Ltd	E.1	56/4/1292
Cheetah Tower Packings	Forbes Technology Ltd	E.4	56/4/711
Chlorine Dioxide generated by Xziox	International Water Solutions Ltd	A.7.3	56/4/998
Citric Acid 50% Solution	Brenntag UK & Ireland	A.5	56/4/1333

List of approved products for use in public water supply in the United Kingdom

Clorious2 Care	Brenntag UK & Ireland	A.9	56/4/1196
CM-151™	Nanostone Water Inc	D.1	56/4/1388
CodeLine RO membranes	Pentair Water India Pvt Ltd	D.2	56/4/288
Conbextra Bedding Mortar	Fosroc International Ltd	C.6	56/4/1271
Continuous Sand Filter	Nijhuis Saur Industries (UK & Ireland)	D.4	56/4/1521
CP Polytec 100	Cork Plastics	B.1.1	56/4/1351
CPE Pressure Vessels-304L and 316L Stainless Steel	CPE Pressure Vessels	E.3	56/4/1135
CST Water Well Casings	Cleveland Steel and Tubes Ltd	B.2	56/4/1430
Deltapor MW and MWA Filter Cartridges	Envirogen Group Ltd	D.1	56/4/1274
Diamond Fabricated pipework assemblies	Diamond Fabrication & Pipework Ltd	B.1.10	56/4/1489
Durapipe ABS	Durapipe Ltd	B.1.4	56/4/660
Durapipe Premium PVC-U-PVC	Durapipe Ltd	B.1.3	56/4/1226
Dyka Grey PVC-U Pipe NGS	Dyka B.V.	B.1.3	56/4/637
egeclean (+)	Egeplast International GmbH	B.1.1	56/4/1157
egeclean 9010	Egeplast International GmbH	B.1.1	56/4/1158
egeclean PE100	Egeplast International GmbH	B.1.1	56/4/1156
egelen PE 100 Blue & egelen PE100 Black	Egeplast International GmbH	B.1.1	56/4/436
Egeplast 9010	Egeplast International GmbH	B.1.1	56/4/1065
egeplast egelen (+) Plus Pipe	Egeplast International GmbH	B.1.1	56/4/1111
egeplast SLA Barrier Pipes	Egeplast International GmbH	B.1.2	56/4/1109
Electrofresh Ductile Iron Pipe	Electrosteel Castings Ltd	B.1.7.1	56/4/992
Electrofresh Plus Pipes	Electrosteel Castings Ltd	B.1.7.2	56/4/537
Eliquo Hydrok Filter Housing Tank	Eliquo Hydrok	D.2	56/4/1386
Envirogen CF Filter Housing	Envirogen Group Ltd	D.2	56/4/1257
ePipe UK	Pipe Restoration Technologies LLC	C.2.3	56/4/995
Erciyas Steel Water Pipe – Cement Lined	Erciyas Celik Boru Sanayi A.S	B.1.7.1	56/4/1047
ES404 Membrane	PCI Membranes	D.1	56/4/215
Eurokote 468 THIXO Brun Rouge-500	Specialist Protective Coatings Ltd	B.1.9	56/4/1389
Eurokote® 468 THIXO 500 Brun Rouge	Axson BS Coatings	B.1.7.1	56/4/1405
European Pipeline Group Svobodny Sokol Ductile Iron Pipe	European Pipeline Group	B.1.7.1	56/4/1114
Fabricated mild steel pipework coated with Jotaguard VA5001	UTS Engineering Ltd	B.1.9	56/4/1324

List of approved products for use in public water supply in the United Kingdom

Fabricated Pipework and Fittings coated with Resicoat R4-FB HKC71R	Freeflow Pipesystems Ltd	B.1.11	56/4/817
Fabricated Pipework and Fittings coated with Resicoat R4-FB HKC71R	Freeflow Pipesystems Ltd	B.1.9	56/4/817
Fabricated Stainless Steel Pipework	FSD Mech Ltd	B.1.10	56/4/1455
Fastfill	Flexcrete Technologies Ltd	C.6	56/4/1162
Flagon Geo P/AT	Soprema UK Ltd	C.4	56/4/856
Flowtite Pipe Uniaxial	Amiblu Technology AS	B.1.6	56/4/1264
Fusion ® V1100	Permastore Ltd	E.1	56/4/1214
Genesol 61	Genesys International Ltd	A.5	56/4/1205
Genesol 704	Genesys International Ltd	A.5	56/4/1319
Genesys CAS	Genesys International Ltd	A.5	56/4/1253
Genesys LF	Genesys International Ltd	A.5	56/4/495
Genesys LF60	Genesys International Ltd	A.5	56/4/783
Genesys LS	Genesys International Ltd	A.5	56/4/781
Genesys SI	Genesys International Ltd	A.5	56/4/593
Genesys SW	Genesys International Ltd	A.5	56/4/524
Geo Textile Terram T700	Berry Global	E.4	56/4/1344
GEROthen® COEX	Gerodur MPM Kunststoffverarbeitung GmbH & Co. KG	B.1.1	56/4/1370
GF DEKADUR PVC-U pressure pipe	George Fischer Sales Ltd	B.1.3	56/4/1231
GF PE100 Black Pipe	George Fischer Sales Ltd	B.1.1	56/4/957
GF PVC-U Inch Pipe	George Fischer Sales Ltd	B.1.3	56/4/1235
GPS B Light Blue Polyethylene Pipe	GPS	B.1.1	56/4/242
GPS Black	GPS	B.1.1	56/4/851
GPS Black 3C	GPS	B.1.1	56/4/871
GPS Blue	GPS	B.1.1	56/4/1026
GPS Blue 3C	GPS	B.1.1	56/4/853
GPS Excel NB Type V	GPS	B.1.1	56/4/1050
GPS N Black Polyethylene Pipe	GPS	B.1.1	56/4/1260
GPS N Blue PE80 Pipe	GPS	B.1.1	56/4/651
GPS Protecta-Line	GPS	B.1.2	56/4/872
GPS Protecta-Line 3c	GPS	B.1.1	56/4/873
GreenPro Lamella Plate Settler	Evergreen Water Solutions	E.4	56/4/1501
Guardsman GT190 Antiscalant for Membrane Systems	Kobell Fluid Technology Ltd	A.5	56/4/1123
HFW 1000	X-FLOW B.V.	D.1	56/4/1139

List of approved products for use in public water supply in the United Kingdom

High Performance SC100 Dark Blue Pipe PE100 pipe including Clean Pipe	Radius Systems Ltd	B.1.1	56/4/939
Hydraflow	Clogrennane Lime Ltd	A.9	56/4/1424
Hydrochoc Butyl Bladder Surge Vessel	Charlatte Reservoirs	E.3	56/4/1016
Hypersperse MDC704i	Veolia Water Technologies & Solutions (Belgium)	A.5	56/4/1499
Hypersperse MDC711	Veolia Water Technologies & Solutions	A.5	56/4/1508
Hypersperse MSI310	Veolia Water Technologies & Solutions (Belgium)	A.9	56/4/1510
iDroloc	SUEZ Advanced Solutions UK Ltd	A.9	56/4/1422
In-Line Coagulation and Adsorption (ILCA)	PWNT Holding B. V.	E.1	56/4/1557
In-Line Coagulation and Adsorption (ILCA)	PWNT Holding B. V.	E.3	56/4/1557
In-Line Coagulation and Adsorption (ILCA)	PWNT Holding B. V.	E.4	56/4/1557
INOX EFH, SFH PFH PSFH,PFH-SGB Stainless Steel Filter Housings	Fileder Filter Systems Ltd	D.2	56/4/1191
INOX SBH,PBH Stainless Steel Bag Housings	Fileder Filter Systems Ltd	D.2	56/4/848
Intercrete 4800	International Paint Ltd	C.6	56/4/1403
Intercrete 4800WS	International Paint Ltd	C.6	56/4/1408
Intercrete 4802	International Paint Ltd	C.6	56/4/1055
Intercrete 4807	International Paint Ltd	C.6	56/4/1404
Intercrete 4820	International Paint Ltd	C.6	56/4/1054
Intercrete 4841	International Paint Ltd	C.5	56/4/1053
Intercrete 4871	International Paint Ltd	C.6	56/4/1056
Internally Coated Spiral Welded (HSAW) Steel Line Pipes with Eurokote 468 THIXO 500 Brun rouge	Borusan Mannesmann Boru San. Ve Tic. A.S.	B.1.9	56/4/1391
Ion exchange colour removal system	Barr + Wray Ltd	A.3.2	56/4/1176
IPF, ICF and NPF model of Dissolved Air Flotation units	Nijhuis Water Technology B.V.	E.4	56/4/620
IPSSSPW01 Stainless Steel Pipework and Fabrications	Equipdata Trading	B.1.10	56/4/1316
IPSSSPW01 Stainless Steel Pipework and Fabrications	Equipdata Trading	E.1	56/4/1316
IPSSSPW01 Stainless Steel Pipework and Fabrications	Equipdata Trading	E.4	56/4/1316

List of approved products for use in public water supply in the United Kingdom

Jacopa Ltd / Nordic Water Lamella Plate Separators	Jacopa Ltd	E.4	56/4/622
Jaguar Range of Storage & Process Tanks & Towers	Forbes Technology Ltd	E.1	56/4/1210
JBF Stainless Steel Pipework and Fabrications	JB Fabrication (Wrexham) Ltd	B.1.10	56/4/1487
J-Guard VA5001 pipes coated with Jotaguard VA5001	Northpoint Ltd	B.1.9	56/4/1511
JKF 304 and 316 Stainless Steel Pipelines	J.K Fabrications Limited	B.1.10	56/4/574
JSAW-JAL-11A	Jindal Saw Ltd	B.1.7.1	56/4/935
JSAW-JAL-1A	Jindal Saw Ltd	B.1.7.1	56/4/933
K Filter Floor	Binnies UK Ltd	E.2	56/4/833
Kalic HSD	Buxton Lime Limited	A.9	56/4/1206
Kleen MCT105	Veolia Water Technologies & Solutions (Belgium)	A.5	56/4/1506
Kleen MCT405	Veolia Water Technologies & Solutions	A.5	56/4/1509
Kleen MCT407	Veolia Water Technologies & Solutions (Belgium)	A.9	56/4/1507
Kleen* MCT524	SUEZ Water Technologies & Solutions	A.5	56/4/1007
Lamella Separator Package (LSF)	Colloide Engineering Systems Ltd	E.4	56/4/1172
Leinster Range of Thermoplastic Tanks	Silotank (Digestors, Silos & Tanks) Ltd	E.1	56/4/498
Leopold Air Scour System	Xylem Water Solutions Zelienople LLC	E.4	56/4/1250
Leopold Type S / SL Underdrain and I.M.S. 200 Media Retainer, I.M.S. 1000 Media Retainer, I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	56/4/1467
Leopold Type SL Underdrain and I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	56/4/371
Leopold Type XA Underdrain and I.M.S. 200 Media Retainer, I.M.S. 1000 Media Retainer, I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	56/4/1468
Lewatit S 5128	Lanxess Deutschland GmbH	A.3.1	56/4/1193
Lion Range of Tanks & Towers	Forbes Technology Ltd	E.1	56/4/1293
LORTUB Steel Water Fittings lined with High Performance Eurokote 468 Thixo	Lortub S.A.S.	B.1.9	56/4/1204
MasterEmaco S420 with MasterSeal 600	Master Builders Solutions UK Ltd	C.6	56/4/1064

List of approved products for use in public water supply in the United Kingdom

MasterSeal 581 with MasterSeal 600	MBCC Construction Chemicals Limited	C.5	56/4/1103
MasterSeal 930 with MasterSeal 933	MBCC Construction Chemicals Limited	C.6	56/4/144
Memcor CMF-L L10N	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/1254
Memcor CMF-L L20N	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/1255
Memcor CMF-L L40N	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/1305
Memcor CMF-M10C Continuous Microfiltration Module (Polypropylene Membranes)	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/975
Memcor CMF-S S10N	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/1256
MEMCOR CMF-S S10T MICROFILTRATION SUBMODULE (SUBMERGED POLYPROPYLENE MEMBRANES) WITH OPTIONAL MEMCOR EF	DuPont Water Solutions (Speciality Electronic Materials UK Ltd)	D.1	56/4/976
MIEX DOC Resin	Ixom Operations Pty Ltd	A.3.1	56/4/550
MIEX Gold	Ixom Operations Pty Ltd	A.3.1	56/4/1140
Mild Steel Well Casing	Skapandi Ltd	B.2	56/4/1429
Mild Steel Well Casting and Screens	Stuwa-Konrad Stukerjurgan GmbH	B.2	56/4/1432
Modular Pontoon	Pontoon Work Ltd	E.4	56/4/1309
Monolevel 844SP	Flexcrete Technologies Ltd	C.6	56/4/1161
Monomix	Flexcrete Technologies Ltd	C.6	56/4/1163
Monomix WS	Flexcrete Technologies Ltd	C.6	56/4/397
NATCEM 35	Natural Cement Distribution Ltd	C.6	56/4/1090
NATCEM AC	Natural Cement Distribution Ltd	C.6	56/4/840
NATCEM D	Natural Cement Distribution Ltd	C.6	56/4/1216
NATCEM DW	Natural Cement Distribution Ltd	C.6	56/4/1049
Noksel Steel Water Pipe - Coated with Thixo 468	Noksel Steel Pipe Co Inc	B.1.9	56/4/1192
Omyalime – MJ 30%	Omya	A.9	56/4/1540
OSTP Stainless Steel pipe and fittings of 12mm bore or greater.	OSTP	B.1.10	56/4/516
Oxiflo 1 & 2 Chlorine Dioxide	Oxiflo Ltd	A.7.3	56/4/1415

List of approved products for use in public water supply in the United Kingdom

Pall Microza UNA-620C microfiltration module	Pall International Sarl	D.1	56/4/795
PE100 High Performance Profuse Pipe Including Factory Sealed	Radius Systems Ltd	B.1.1	56/4/1243
PE100 High Performance Profuse Pipe Including Factory Sealed	Radius Systems Ltd	B.1.1	56/4/943
Peak Pipe Systems	Peak Pipe Systems	B.1.1	56/4/548
PERMASTORE STAINLESS STEEL	Permastore Ltd	E.1	56/4/594
PEXGOL	GOLAN Plastic Products Ltd	B.2	56/4/1259
Pile Cloth Media Filter (PCMF) DW2/10 - DW27/135	Mecana Umwelttechnik GmbH	D.1	56/4/1215
Pile Cloth Media Filter (PCMF) DW2/10 to DW27/135 with UFS-9-DW cloth	Mecana Umwelttechnik GmbH	D.1	56/4/1387
PIPELIFE BLACK PE100-RC PIPE	Pipelife Norge AS	B.1	56/4/1488
Pipes and fittings lined with Eurokote 468 Thixo	Northpoint Ltd	B.1.9	56/4/1209
Pipes, Fittings, Steelwork & Tank plates coated with Resicoat R4-FB HKC71R	Northpoint Ltd	B.1.9	56/4/659
Pipework and tanks for use with drinking water	Salt Separation Services Ltd	B.1.10	56/4/1477
Pipework and tanks for use with drinking water	Salt Separation Services Ltd	E.1	56/4/1477
Pipework and tanks for use with drinking water	Salt Separation Services Ltd	E.3	56/4/1477
Plasmor U Blocks	Plasmor Ltd	E.2	56/4/988
Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.2	56/4/857
Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes (ME3444)	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.2	56/4/1516
Polypipe Black PE100 Polyethylene Pipes (TUB121N3000)	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/1343
Polypipe Blue PE100 Polyethylene Pipes (TUB124N 2025)	Polypipe Ltd (Trading as Polypipe Building Products)	B.1.1	56/4/1514
Power Plas ® BC850 Baffle Curtain	Power Plastics Ltd	C.4	56/4/1350
PowerPlas ® TL850 Tank Liner	Power Plastics Ltd	C.4	56/4/1385
Powerrun Fabricated Coated Carbon Steel Pipework	Powerrun Pipe-Mech Ltd	B.1.9	56/4/1439
Powerrun fabricated stainless steel pipework	Powerrun Pipe-Mech Ltd	B.1.10	56/4/769
Premcrete Hydroseal FX	Premcrete Ltd.	C.5	56/4/1356
Premcrete Teknocem HB50	Premcrete Ltd.	C.6	56/4/1357

List of approved products for use in public water supply in the United Kingdom

Premcrete Teknolevel FS	Premcrete Ltd.	C.5	56/4/1359
Premcrete Teknoprime 841	Premcrete Ltd.	C.6	56/4/1360
PRESSURE FILTRATION KIT DF FP/FDN 800÷3 500	Dynamik Filtr Nocon i Wspólnicy Spółka jawna	D.4	56/4/1272
Pressure Vessels & Stainless Steel Pipework	A.W.E. (Anderson Water Equipment) Limited	E.3	56/4/1533
Pressure-Tight Doors (TT7.1, TT7.Z, TT7.R and TT7.30)	Huber Technology	E.4	56/4/1445
Purafloc TM 001	JFI Limited	A.9	56/4/1355
Purafloc TM 001	Clinty Chemicals Limited	A.9	56/4/1378
Purolite A520E nitrate selective anion exchange resin	Purolite International Ltd	A.3.1	56/4/11
Qual-plast HDPE Pipe	Pipelife Ireland Limited	B.1.1	56/4/997
Qual-plast MDPE Pipe	Pipelife Ireland Limited	B.1.1	56/4/240
QualPLAST Polyethylene MDPE co- extruded pipe	Pipelife Ireland Limited	B.1.1	56/4/1282
Quantum Pressure Vessels- 304L	Quantum Engineering Developments Ltd	E.3	56/4/1132
Quantum Pressure Vessels- 316L	Quantum Engineering Developments Ltd	E.3	56/4/1133
Renderoc Plug 20	Fosroc International Ltd	C.6	56/4/297
RENO 100	Idrotherm 2000 spa	B.1.1	56/4/1168
Reno 100 Plus	Idrotherm 2000 spa	B.1.1	56/4/1384
Resicoat R4-FB Coated Steel Pipes and Fittings	Leyfos Plastics Limited	B.1.9	56/4/1460
Resiline 320	Resimac Ltd	C.2.2	56/4/1390
Resinex KW-H	Jacobi Carbons	A.3.1	56/4/1151
Rivertex® APO850 PowerPlas (Grey)	Rivertex UK Ltd	Annex 3D	56/4/1532
RoCide DB20	Kurita UK Ltd	A.5	56/4/964
RoClean L211	Kurita UK Ltd	A.5	56/4/945
RoClean L403	Kurita UK Ltd	A.5	56/4/855
RoClean P111	Kurita UK Ltd	A.5	56/4/737
RoClean P303	Kurita UK Ltd	A.5	56/4/1544
Safe 10	Centraltubi SPA	B.1.1	56/4/1366
SC100 (PE100) XL large diameter / heavy wall dark blue potable water pipe	Radius Systems Ltd	B.1.1	56/4/1146
SEAQUEST	Aqua Smart Inc.	A.9	56/4/202
SELCOPERM System SES 125-2000	Grundfos Holding A/S	A.7.2	56/4/864
Sensorline	Sensor (UK) Ltd	C.4	56/4/1066
Sensorline	Sensor (UK) Ltd	E.4	56/4/1066

List of approved products for use in public water supply in the United Kingdom

Shotcrete 513	Natural Cement Distribution Ltd	C.6	56/4/1089
Sikadur Combiflex SG Jointing System, using SikaDur 31DW	Sika Ltd	C.6	56/4/94
Sikadur-Combiflex®-930 with Sikadur-Combiflex®-933	Sika Ltd	C.6	56/4/1569
Sikagard 62	Sika Ltd	C.3.1	56/4/197
Sikalastic® M 808	MBCC Construction Chemicals Limited	C.3.2	56/4/1080
SikaTop®-581 Seal	MBCC Construction Chemicals Limited	C.5	56/4/1227
SikaTop®-588 Seal	MBCC Construction Chemicals Limited	C.5	56/4/1128
SikaTop®-586 Seal	Sika Ltd	C.5	56/4/86
Silver Bullets 2000	BioBullets Ltd	A.9	56/4/1000
Single and Multiple Cartridge & Bag Filter Housings and Interconnecting pipework	Amazon Filters Ltd	D.2	56/4/879
Sirofloc Magnetite TM M-10	Northern Ireland Water	A.1.3	56/4/1338
Stainless Steel ANSI Metric ISO Pipe, Stainless Steel ANSI Metric ISO Tube, Stainless Steel ANSI Metric ISO Fittings	Righton & Blackburns Ltd	B.1.10	56/4/1462
Stainless Steel DAF	Jacopa Ltd	E.4	56/4/1180
Stainless Steel Fabrications and Pipework	Glasswell and Last Ltd	B.1.10	56/4/1474
Stainless Steel Fabrications and Pipework	Glasswell and Last Ltd	E.1	56/4/1474
Stainless Steel Fabrications and Pipework	Glasswell and Last Ltd	E.4	56/4/1474
Stainless Steel Fabrications and Pipework	Panks Engineers Limited	B.1.10	56/4/1458
Stainless Steel Fabrications and Pipework	Waveneys	B.1.10	56/4/1442
Stainless Steel Fabrications and Pipework	Waveneys	E.1	56/4/1442
Stainless Steel Fabrications and Pipework	Waveneys	E.4	56/4/1442
Stainless Steel fabrications and pipework for water use	Fabcon Food Systems Ltd	B.1.10	56/4/1466
Stainless steel fabrications: Tanks, Pipework, Support and Access Systems	Atom Fabs Ltd	B.1.10	56/4/1484

List of approved products for use in public water supply in the United Kingdom

Stainless steel fabrications: Tanks, Pipework, Support and Access Systems	Atom Fabs Ltd	E.1	56/4/1484
Stainless steel fabrications: Tanks, Pipework, Support and Access Systems	Atom Fabs Ltd	E.4	56/4/1484
Stainless steel flanged pipes	Direct Engineering & Site Services Ltd	B.1.10	56/4/1443
Stainless steel floor plates, weirs, pipework and tanks	Western Carbons Ltd	B.1.10	56/4/1303
Stainless steel floor plates, weirs, pipework and tanks	Western Carbons Ltd	E.1	56/4/1303
Stainless steel floor plates, weirs, pipework and tanks	Western Carbons Ltd	E.4	56/4/1303
Stainless Steel Grade 316L Potable Water Reservoir Tanks	Powerrun Pipe-Mech Ltd	E.1	56/4/611
Stainless Steel Metric ISO & ANSI welded pipe and fittings	DH Stainless Ltd	B.1.10	56/4/773
Stainless Steel Penstock	Waterfront Fluid Controls Ltd	E.4	56/4/1531
Stainless Steel Pipework	Alpha Plus Ltd	B.1.10	56/4/1564
Stainless Steel Pipework	Water Engineering Services Fabrication	B.1.10	56/4/1493
Stainless Steel Pipework & Fittings - Flanged/Screwed - All diameters & Grades	George Green (Keighley) Ltd	B.1.10	56/4/699
Stainless Steel Pipework and Fabrications	AJ Engineering and Construction Services Ltd	B.1.10	56/4/1220
Stainless Steel Pipework and Fabrications	AJ Engineering and Construction Services Ltd	E.4	56/4/1220
Stainless Steel Pipework and Fabrications	Berry & Escott Engineering	B.1.10	56/4/1362
Stainless Steel Pipework and Fabrications	Berry & Escott Engineering	E.1	56/4/1362
Stainless steel process pipework systems	Ross-shire Engineering Ltd	B.1.10	56/4/1034
Stainless Steel Products	Veolia Water Technologies & Solutions (Hungary)	B.1.10	56/4/1371
Stainless Steel Products	Veolia Water Technologies & Solutions (Hungary)	E.1	56/4/1371
Stainless Steel Products	Veolia Water Technologies & Solutions (Hungary)	E.4	56/4/1371
Stainless Steel Screens, Casings, Fittings and Accessories	Stuwa-Konrad Stukerjurgan GmbH	B.2	56/4/1060
Stainless Steel Tanks & Pipework	EPS Group	B.1.10	56/4/1267

List of approved products for use in public water supply in the United Kingdom

Stainless Steel Tanks & Pipework	EPS Group	E.1	56/4/1267
Stainless Steel Tanks and Launderers	Allied Storage Tank Ltd	E.1	56/4/1258
Stainless Steel Tube, Stainless Steel pipe	Aalco Metals Ltd (formerly Amari Metals Ltd)	B.1.10	56/4/738
Stainless Steel Tube, Stainless Steel pipe	Aalco Metals Ltd (formerly Amari Metals Ltd)	E.4	56/4/738
Stainless Steel Tubings and Fittings	BSS Industrial	B.1.10	56/4/1017
Stainless Steel Vessels	Vessco Engineering Ltd	E.4	56/4/1539
Stainless Steel Water Tanks	Ross-shire Engineering Ltd	E.1	56/4/1381
Stainless Steel Water Tanks	Sayers Road Tankers Ltd	E.1	56/4/1028
Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	B.1.10	56/4/567
Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	E.1	56/4/567
Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	E.4	56/4/567
Steel pipe coated with Eurokote 468 Thixo	Soluciones Tubulares Sostenibles SL	B.1.9	56/4/1203
Steel Reinforcement Protector 841	Flexcrete Technologies Ltd	C.6	56/4/1164
STUWA Stainless Steel Riser Pipes	Stuwa-Konrad Stukerjurgan GmbH	B.2	56/4/1077
Subcoil	Radius Subterra – a part of RadiusPlus Ltd	B.1.1	56/4/461
Subcote FLP II	Radius Systems Ltd	C.2.2	56/4/1286
Suspended Ion Exchange (SIX)	PWNT Holding B. V.	E.4	56/4/1171
System Cement Mortar Lined Ductile Iron Pipe	Superior Pipeline Products Ltd	B.1.7.1	56/4/990
System CL	Saint-Gobain PAM UK Ltd	B.1.7.1	56/4/283
System XL	Saint-Gobain PAM UK Ltd	B.1.7.2	56/4/1317
Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	B.1.10	56/4/1107
Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	E.1	56/4/1107

List of approved products for use in public water supply in the United Kingdom

Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	E.4	56/4/1107
Tanks for transportation of drinking water	Crossland Tankers Ltd	B.3.2	56/4/792
Tetra LP Block System	De Nora Water Technologies UK Services Ltd	E.2	56/4/522
Thycal	Industrial Chemicals Ltd	A.9	56/4/1025
Tiefill	Flexcrete Technologies Ltd	C.6	56/4/1287
TOM PVC-O	Molecor Tecnología SL	B.1.3	56/4/1568
TP Chlor	Brenntag UK & Ireland	A.9	56/4/979
TP Chlor plus	Brenntag UK & Ireland	A.9	56/4/1190
Trifusion ®	Permastore Ltd	E.1	56/4/1213
Tru Bore - Stainless Steel Tube and associated products	Special Metric Materials Ltd	B.1.10	56/4/1465
Tru Bore - Stainless Steel Tube and associated products	Special Metric Materials Ltd	E.4	56/4/1465
TUBEdek FS41.50/84 PP	ENEXIO 2H Water Technologies Ltd	E.4	56/4/878
Ultrafiltration element ZW700B-8060/UF10/7B/X/0.8/40	SUEZ Water Technologies and Solutions Hungary Kft	D.1	56/4/1126
Ultralox 40	WCS Services Ltd (trading as B&V Chemicals)	A.9	56/4/1530
Ultrastore Tank System	STORTEC Engineering Limited	E.1	56/4/1456
VANDEX BB 75	Vandex isoliermittel-Gesellschaft m.b.H	C.5	56/4/1092
VANDEX SUPER	Vandex isoliermittel-Gesellschaft m.b.H	C.5	56/4/1098
VANDEX UNIMORTAR 1	Vandex isoliermittel-Gesellschaft m.b.H	C.5	56/4/1524
Velocitek OVF Filter Vessel	Hydro-Gen Engineering Ltd	D.4	56/4/1400
VIP-WECO HYBRID LINER UNIT	VIP-Polymers Limited	C.6	56/4/1479
VIP-WECO Stainless Steel Tension Bands	VIP-Polymers Limited	E.4	56/4/1481
Vitec 3000	Kurita UK Ltd	A.5	56/4/457
Vitec 4000	Kurita UK Ltd	A.5	56/4/1529
Vitec 7000	Kurita UK Ltd	A.5	56/4/801
Vitec 7000a	Kurita UK Ltd	A.5	56/4/869
VOLUTE DUO Dewatering Press and optional Inline Mixer	AMCON Europe s.r.o	E.4	56/4/1471
Wallace & Tieman OSEC® B-PAK	Evoqua Water Technologies Ltd	A.7.2	56/4/1451

List of approved products for use in public water supply in the United Kingdom

Wallace & Tieman OSEC® B-PLUS	Evoqua Water Technologies GmbH (Germany)	A.7.2	56/4/1450
Wallace & Tiernan OSEC® L	Evoqua Water Technologies GmbH (Germany)	A.7.2	56/4/775
Water Pipe Lining	Aqualiner Ltd	C.1	56/4/910
Water2U Tanker V1	Water2U - Chard Truck Services	B.3.2	56/4/1485
Waterstop	Natural Cement Distribution Ltd	C.6	56/4/1217
Wavin Compact Pipe	Public Sewer Services Limited	B.1.1	56/4/1417
Wavin Compact Pipe	Public Sewer Services Limited	C.1	56/4/1417
Weholite Pipe and Panels	SDS Pipe Systems Ltd	B.1.1	56/4/513
Weholite Pipe and Panels	SDS Pipe Systems Ltd	E.1	56/4/513
Whale Drinking Water Bowser	Whale Tankers Ltd	B.3.2	56/4/662
WTP RO 411	Water Treatment Products Limited	A.5	56/4/821
WTP RO 413	Water Treatment Products Limited	A.5	56/4/822
XF-series - modules XF40, XF40C, XF42 and XF 53	X-FLOW B.V.	D.1	56/4/324
XF-series - modules XF55, XF64 and XF75	X-FLOW B.V.	D.1	56/4/967
Xypex Concentrate	Xypex (UK) Ltd	C.5	56/4/1261
Xypex Modified	Xypex (UK) Ltd	C.5	56/4/1262
Xypex Patch'n Plug	Xypex (UK) Ltd	C.5	56/4/1100
ZeeWeed® 700B-10060 Membrane Module	SUEZ Water Technologies and Solutions Hungary Kft	D.1	56/4/1398
ZeeWeed® 700B-10072 (RMS)	SUEZ Water Technologies and Solutions Hungary Kft	D.1	56/4/1425
ZeeWeed 1500 Series	Veolia Water Technologies & Solutions (Hungary)	D.1	56/4/1013
ZeeWeed 500D Module and Cassette; 500D (340, 370), 500D (440), 500Ds (350)	Veolia Water Technologies & Solutions (Hungary)	D.1	56/4/835
ZeeWeed 700B family of modules	Veolia Water Technologies & Solutions (Hungary)	D.1	56/4/1464